


# PROBLEM SUMMARY

Sample Rating Trend




**WATER**



Machine Id  
**1 EAST**  
Component  
**Heat Transfer Fluid**  
Fluid  
**SUMMITT PGI 150 (--- GAL)**



## COMPONENT CONDITION SUMMARY



## RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status				<b>ABNORMAL</b>	---	---
Water	%	ASTM D6304	>0.01	▲ <b>0.218</b>	---	---
ppm Water	ppm	ASTM D6304	>100	▲ <b>2180</b>	---	---
Particles >4µm		ASTM D7647	>640	▲ <b>2867</b>	---	---
Particles >6µm		ASTM D7647	>320	▲ <b>578</b>	---	---
Oil Cleanliness		ISO 4406 (c)	>16/15/13	▲ <b>19/16/12</b>	---	---
Acid Number (AN)	mg KOH/g	ASTM D8045		▲ <b>0.125</b>	---	---

Customer Id: BLUGRANE  
Sample No.: TO1010420  
Lab Number: 04590918  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Jonathan Hester +1 919-379-4092 x4092  
[jhester@wearcheckusa.com](mailto:jhester@wearcheckusa.com)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)


## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	MISSED	Dec 10 2021	?	We recommend you service the filters on this component if applicable.

## HISTORICAL DIAGNOSIS

# OIL ANALYSIS REPORT

Sample Rating Trend



**WATER**



Machine Id  
**1 EAST**  
 Component  
**Heat Transfer Fluid**  
 Fluid  
**SUMMITT PGI 150 (--- GAL)**

**DIAGNOSIS**

**Recommendation**  
 We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

**Wear**  
 All component wear rates are normal.

**Contamination**  
 There is a high amount of silt (particulates < 14 microns in size) present in the oil. There is a moderate concentration of water present in the oil.

**Fluid Condition**  
 The AN level is at the top-end of the recommended limit.

SAMPLE INFORMATION	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>TO1010420</b>	---	---
Sample Date	Client Info		<b>08 Nov 2018</b>	---	---
Machine Age	Client Info		<b>0</b>	---	---
Oil Age	Client Info		<b>0</b>	---	---
Oil Changed	Client Info		<b>Not Chngd</b>	---	---
Sample Status			<b>ABNORMAL</b>	---	---

WEAR METALS	method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m	>50	<b>&lt;1</b>	---	---
Chromium	ppm ASTM D5185m	>10	<b>0</b>	---	---
Nickel	ppm ASTM D5185m		<b>0</b>	---	---
Titanium	ppm ASTM D5185m		<b>0</b>	---	---
Silver	ppm ASTM D5185m		<b>0</b>	---	---
Aluminum	ppm ASTM D5185m	>10	<b>0</b>	---	---
Lead	ppm ASTM D5185m	>10	<b>0</b>	---	---
Copper	ppm ASTM D5185m	>50	<b>&lt;1</b>	---	---
Tin	ppm ASTM D5185m	>10	<b>&lt;1</b>	---	---
Antimony	ppm ASTM D5185m		<b>0</b>	---	---
Vanadium	ppm ASTM D5185m		<b>0</b>	---	---
Cadmium	ppm ASTM D5185m		<b>0</b>	---	---






ADDITIVES	method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m		<b>0</b>	---	---
Barium	ppm ASTM D5185m		<b>0</b>	---	---
Molybdenum	ppm ASTM D5185m		<b>0</b>	---	---
Manganese	ppm ASTM D5185m		<b>&lt;1</b>	---	---
Magnesium	ppm ASTM D5185m		<b>0</b>	---	---
Calcium	ppm ASTM D5185m		<b>1</b>	---	---
Phosphorus	ppm ASTM D5185m		<b>6</b>	---	---
Zinc	ppm ASTM D5185m		<b>&lt;1</b>	---	---
Sulfur	ppm ASTM D5185m		<b>162</b>	---	---

CONTAMINANTS	method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m	>15	<b>&lt;1</b>	---	---
Sodium	ppm ASTM D5185m		<b>&lt;1</b>	---	---
Potassium	ppm ASTM D5185m	>20	<b>&lt;1</b>	---	---
Water	% ASTM D6304	>0.01	<b>▲ 0.218</b>	---	---
ppm Water	ppm ASTM D6304	>100	<b>▲ 2180</b>	---	---

FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>640	<b>▲ 2867</b>	---	---
Particles >6µm	ASTM D7647	>320	<b>▲ 578</b>	---	---
Particles >14µm	ASTM D7647	>80	<b>24</b>	---	---
Particles >21µm	ASTM D7647	>20	<b>4</b>	---	---
Particles >38µm	ASTM D7647	>4	<b>0</b>	---	---
Particles >71µm	ASTM D7647	>3	<b>0</b>	---	---
Oil Cleanliness	ISO 4406 (c)	>16/15/13	<b>▲ 19/16/12</b>	---	---

FLUID DEGRADATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D8045		<b>▲ 0.125</b>	---	---

# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.01	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	140.0	---	---
Visc @ 100°C	cSt	ASTM D445	23.5	---	---
Viscosity Index (VI)	Scale	ASTM D2270	199	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color				no image	no image
Bottom				no image	no image

### GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : TO1010420 **Received** : 12 Nov 2018  
**Lab Number** : 04590918 **Diagnosed** : 13 Nov 2018  
**Unique Number** : 8394896 **Diagnostician** : Jonathan Hester  
**Test Package** : IND 2 ( Additional Tests: KF, KV100, PrtCount, VI )

**ERGON - GRAND ISLAND**  
 4112 N ACADEMY RD  
 GRAND ISLAND, NE  
 US 68801  
 Contact: SHANE THYNE  
 Shane.Thyne@ergon.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)