

Area [10117491]

PROBLEM SUMMARY

GARDNER DENVER C-8 (S/N S521766)


Compressor

GARDNER DENVER AEON 9000 TH (--- GAL)

Sample Rating Trend Jan2018 May2018 Aug2018 Dec2018



COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.

PROBLEMATIC TEST RESULTS											
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL					
Water	%	ASTM D6304	>0.1	△ 0.178	△ 0.125	▲ 0.294					
ppm Water	ppm	ASTM D6304	>1000	1780	<u>1250</u>	2940					
Debris	scalar	*Visual	NONE	▲ MODER	▲ MODER	▲ MODER					
Appearance	scalar	*Visual	NORML	▲ HAZY	▲ LAYRD	▲ HAZY					
Free Water	scalar	*Visual		2.0	<u>^</u> 2.0	△ 5.0					

Customer Id: WESLONWC Sample No.: WCI2335322 Lab Number: 04642025 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS Action **Status** Date Done By Description We advise that you follow the water drain-off procedure for this component, Water Drain-off MISSED Apr 18 2019 ? and use off-line filtration to improve the cleanliness of the system fluid. Resample **MISSED** Apr 18 2019 We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of Alert particles present in this sample.

HISTORICAL DIAGNOSIS

28 Aug 2018 Diag: Jonathan Hester

WATER



We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Free water present. There is a light concentration of water present in the oil. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid.



25 May 2018 Diag: Jonathan Hester

WAIER



We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Free water present. There is a light concentration of water present in the oil. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid.

view report

24 Jan 2018 Diag: Doug Bogart

WATER



We advise that you follow the water drain-off procedure for this component. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a moderate amount of particulates present in the oil. There is a light concentration of water present in the oil. Free water present. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.






OIL ANALYSIS REPORT

Area [10117491] GARDNER DENVER C-8 (S/N S521766)

Compressor

GARDNER DENVER AEON 9000 TH (--- GAL)





DIAGNOSIS

Recommendation

We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.

All component wear rates are normal.

Contamination

Appearance is hazy. Free water present. There is a light concentration of water present in the oil. Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORM	MATION	method	limit/base	current	history 1	history 2
Sample Number		Client Info		WCI2335322	WCI2288186	WCI2333178
Sample Date		Client Info		20 Dec 2018	28 Aug 2018	25 May 2018
Machine Age	hrs	Client Info		12121	9376	6782
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	2	1	3
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>10	<1	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	0	<1	<1
Lead		ASTM D5185m	>25	<1	1	2
	ppm	ASTM D5185m	>50	2	1	<1
Copper Tin	ppm	ASTM D5185m	>15		0	0
	ppm		>10	<1 <1	2	0
Antimony	ppm	ASTM D5185m ASTM D5185m				
Vanadium	ppm			0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m		<1	2	<1
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	<1
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m		0	1	0
Calcium	ppm	ASTM D5185m		0	<1	0
Phosphorus	ppm	ASTM D5185m		776	708	694
Zinc	ppm	ASTM D5185m		1	3	2
Sulfur	ppm	ASTM D5185m		54	44	11
CONTAMINANTS		method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	<1	<1	<1
Sodium	ppm	ASTM D5185m		0	0	0
Potassium	ppm	ASTM D5185m	>20	0	<1	<1
Water	%	ASTM D6304	>0.1	<u> </u>	△ 0.125	△ 0.294
ppm Water	ppm	ASTM D6304	>1000	1780	<u>▲</u> 1250	△ 2940
FLUID CLEANLIN	IESS	method	limit/base	current	history 1	history 2
Particles >4µm		ASTM D7647	>10000			
Particles >6µm		ASTM D7647	>2500			
Particles >14µm		ASTM D7647	>320			
Particles >21µm		ASTM D7647	>80			
Particles >38µm		ASTM D7647	>20			
Particles >71μm		ASTM D7647	>4			
Oil Cleanliness		ISO 4406 (c)	>20/18/15			
	TION	m other al	limit/lease	O	bictomed	higtom, C
FLUID DEGRADA	HON	method	limit/base	current	history 1	history 2

0.532



OIL ANALYSIS REPORT







Laboratory Sample No. Lab Number **Unique Number**

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : WCI2335322

40

: 04642025

: 8483461

Received : 01 Feb 2019 Diagnosed : 05 Feb 2019 Diagnostician : Jonathan Hester Acid Number

0.60 0.60 0.60 0.40

0.00 G

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) 2290 CALLAHAN RD LONGVIEW, TX US 75607

Contact: ROB WALLIN rwallin@westlake.com T: (903)242-7576

Contact/Location: ROB WALLIN - WESLONWC

F: (903)758-9521