


PROBLEM SUMMARY

Sample Rating Trend



DIRT




CHW-017

Component **Main Grease**

MOBIL (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC T	EST RE	SULTS				
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
Silicon	ppm	ASTM D5185m	>+300	<u> </u>	<u></u> 1019	<u>▲</u> 831

Customer Id: MITCAL Sample No.: MHII2259083 Lab Number: 04651605 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

23 May 2017 Diag: Doug Bogart

DIRT



No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. Elemental level of silicon (Si) above normal. The AN level is acceptable for this fluid.



26 May 2016 Diag: Jonathan Hester

DIRT



No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. Elemental level of silicon (Si) above normal. The AN level is acceptable for this fluid.



20 May 2015 Diag: Jonathan Hester

DIRT




No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. Elemental level of silicon (Si) above normal. The AN level is acceptable for this fluid.





OIL ANALYSIS REPORT

Sample Rating Trend





CHW-017

Main Grease

MOBIL (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Grease Condition

The AN level is acceptable for this fluid.


Contaminants

Elemental level of silicon (Si) above normal.

		Apr2013	Oct2014 May2015	May2015 May2016 May2017	Sep2018	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		MHII2259083	MHII2276842	MHI004808
Sample Date		Client Info		06 Sep 2018	23 May 2017	26 May 2016
Machine Age	hrs	Client Info		0	0	24159
Grease Age	hrs	Client Info		0	0	0
Grease Serviced		Client Info		N/A	N/A	Not Changd
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184	>200	95	40	65.0
Iron	ppm	ASTM D5185m	>30000	148	110	84
Chromium	ppm	ASTM D5185m	>150	2	<1	1
Nickel	ppm	ASTM D5185m		2	<1	0
Titanium	ppm	ASTM D5185m		0	0	<1
Silver	ppm	ASTM D5185m		1	0	<1
Aluminum	ppm	ASTM D5185m		<1	0	3
Lead	ppm	ASTM D5185m		0	0	0
Copper	ppm	ASTM D5185m		9	2	8
Tin	ppm	ASTM D5185m		0	12	2
Antimony	ppm	ASTM D5185m		0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		2	7	1
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	8
Manganese	ppm	ASTM D5185m		1	2	<1
Magnesium	ppm	ASTM D5185m		0	0	0
Calcium	ppm	ASTM D5185m		4	0	43
Phosphorus	ppm	ASTM D5185m		1784	2395	1932
Zinc	ppm	ASTM D5185m		2831	3368	3018
Sulfur	ppm	ASTM D5185m		7662	10294	8563
CONTAMINANTS	6	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>+300	<u> </u>	▲ 1019	▲ 831
Sodium	ppm	ASTM D5185m		9	9	4
Potassium	ppm	ASTM D5185m	>20	5	0	55
Water	%	ASTM D6304		0.044	0.092	0.071
ppm Water	ppm	ASTM D6304	>5000	440	920	710
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		1.34	1.57	0.159



OIL ANALYSIS REPORT



* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: