


OIL ANALYSIS REPORT

Sample Rating Trend







Machine Id **3270694** Component

Gearbox

MOBIL GEAR (66 QTS)

וט	IA	Gľ	VО	SI	S	

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				Apr2019		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WCI2344646		
Sample Date		Client Info		26 Apr 2019		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>0.2	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	22		
Chromium	ppm	ASTM D5185m	>15	<1		
Nickel	ppm	ASTM D5185m	>15	<1		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	2		
Lead	ppm	ASTM D5185m	>100	<1		
Copper	ppm	ASTM D5185m	>200	45		
Tin	ppm	ASTM D5185m	>25	0		
Antimony	ppm	ASTM D5185m		<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		3		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		4		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		<1		
Phosphorus	ppm	ASTM D5185m		136		
Zinc	ppm	ASTM D5185m		30		
Sulfur	ppm	ASTM D5185m		6409		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	17		
Sodium	ppm	ASTM D5185m		1		
Potassium	ppm	ASTM D5185m	>20	11		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2


0.580

Acid Number (AN)

mg KOH/g ASTM D8045



OIL ANALYSIS REPORT







Certificate L2367

Laboratory Sample No. Lab Number Unique Number

Test Package : IND 2

: WCI2344646 : 04703459 : 8579981

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : 30 Apr 2019 Received Diagnosed :01 May 2019 Diagnostician

: Don Baldridge

PO BOX 727 CHATSWORTH, IL US 60921 Contact: JUSTIN MYER

PRINSCO - CHATSWORTH

justin.myer@prinsco.com

T: F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)