




PROBLEM SUMMARY

Area
RAW MATS
 Machine Id
ROTATING ASSY REFINER 2
 Component
Gearbox
 Fluid
MOBIL SHC 627 (2 GAL)



Sample Rating Trend



WATER



COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	SEVERE	SEVERE
Water	%	ASTM D6304	>0.2	▲ 0.217	0.003	0.003
ppm Water	ppm	ASTM D6304	>2000	▲ 2170	30	30
Particles >4µm		ASTM D7647	>1300	● 3218	● 118411	● 179829
Particles >6µm		ASTM D7647	>320	● 1753	● 20376	● 62170
Particles >14µm		ASTM D7647	>40	● 298	● 171	● 1731
Particles >21µm		ASTM D7647	>10	● 100	● 31	● 279
Particles >38µm		ASTM D7647	>3	● 15	2	● 4
Oil Cleanliness		ISO 4406 (c)	>17/15/12	● 19/18/15	● 24/22/15	● 25/23/18
Free Water	scalar	*Visual		● 2.0	NEG	NEG

Customer Id: JAMPUL
 Sample No.: WC0341559
 Lab Number: 04771259
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Jonathan Hester +1 919-379-4092 x4092
jhester@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Water Drain-off	---	---	?	We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid.

HISTORICAL DIAGNOSIS

01 Jul 2019 Diag: Jonathan Hester

ISO



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



03 Jun 2019 Diag: Don Baldrige

ISO



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



30 Apr 2019 Diag: Jonathan Hester

ISO



We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Area
RAW MATS
 Machine Id
ROTATING ASSY REFINER 2
 Component
Gearbox
 Fluid
MOBIL SHC 627 (2 GAL)

DIAGNOSIS

Recommendation

We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil. Free water present. There is a light concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0341559	WC0351487	WC0341566
Sample Date	Client Info		31 Jul 2019	01 Jul 2019	03 Jun 2019
Machine Age	days	Client Info	0	0	0
Oil Age	days	Client Info	0	0	0
Oil Changed	Client Info		Not Changed	Not Changed	Not Changed
Sample Status			SEVERE	SEVERE	SEVERE

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184		38	25	51
Iron	ppm	ASTM D5185m >200	13	17	28
Chromium	ppm	ASTM D5185m >15	<1	<1	<1
Nickel	ppm	ASTM D5185m >15	0	0	<1
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	<1	<1	<1
Lead	ppm	ASTM D5185m >100	0	0	<1
Copper	ppm	ASTM D5185m >200	0	0	0
Tin	ppm	ASTM D5185m >25	<1	0	0
Antimony	ppm	ASTM D5185m	0	0	0
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	<1	<1
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0
Manganese	ppm	ASTM D5185m	<1	<1	0
Magnesium	ppm	ASTM D5185m	0	<1	0
Calcium	ppm	ASTM D5185m	2	2	0
Phosphorus	ppm	ASTM D5185m	388	401	436
Zinc	ppm	ASTM D5185m	0	<1	0
Sulfur	ppm	ASTM D5185m	5	174	64

CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	3	2	3
Sodium	ppm	ASTM D5185m	<1	<1	<1
Potassium	ppm	ASTM D5185m >20	0	<1	0
Water	%	ASTM D6304 >0.2	▲ 0.217	0.003	0.003
ppm Water	ppm	ASTM D6304 >2000	▲ 2170	30	30

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>1300	3218	118411	179829
Particles >6µm	ASTM D7647	>320	1753	20376	62170
Particles >14µm	ASTM D7647	>40	298	171	1731
Particles >21µm	ASTM D7647	>10	100	31	279
Particles >38µm	ASTM D7647	>3	15	2	4
Particles >71µm	ASTM D7647	>3	1	0	0
Oil Cleanliness	ISO 4406 (c)	>17/15/12	19/18/15	24/22/15	25/23/18



OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.463	0.531	0.503





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	MODER	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	▲ LAYRD	NORML	NORML
Odor	scalar	*Visual	NORML	▲ NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	0.2%	NEG	NEG
Free Water	scalar	*Visual		◆ 2.0	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	99.1	102	102	102

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0341559 **Received** : 07 Aug 2019
Lab Number : 04771259 **Tested** : 08 Aug 2019
Unique Number : 8694051 **Diagnosed** : 08 Aug 2019 - Jonathan Hester
Test Package : IND 2 (Additional Tests: KF, PQ, PrtCount)
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

JAMES HARDIE BUILDING PRODUCTS - PULASKI
 1000 JAMES HARDIE WAY
 PULASKI, VA
 US 24031
 Contact: MICHAEL MITCHELL
 mike.mitchell@jameshardie.com
 T:
 F: