

# **PROBLEM SUMMARY**

#### Area [10664528] Machine Id INGERSOLL RAND SSR-UP6-30-125 100 C-1 (S/N CBV231518) Component

Compressor

1.2

1.0

0.7 vater 8

0.2

0.0


Sep 18/

🔺 Water

Severe

COMPRESSOR OIL (PAG) ISO 46 (--- GAL)

### COMPONENT CONDITION SUMMARY



Sample Rating Trend

WATER

Sep18/19

### RECOMMENDATION

Abnormal

We advise that you follow the water drain-off procedure for this component. We recommend you service the filters on this component. Resample at the next service interval to monitor.

### PROBLEMATIC TEST RESULTS

Sep18/19

10 20k

10k

5k

0k

Sep18/19

PROBLEMATIC	ESTRE	SUL15			
Sample Status				ABNORMAL	 
Water	%	ASTM D6304	>0.1	<b>A</b> 0.550	 
ppm Water	ppm	ASTM D6304	>1000	<b>6</b> 5500	 
Particles >4µm		ASTM D7647	>10000	<u> </u>	 
Particles >6µm		ASTM D7647	>2500	<u> </u>	 
Particles >14µm		ASTM D7647	>320	<u> </u>	 
Particles >21µm		ASTM D7647	>80	<u> </u>	 
Oil Cleanliness		ISO 4406 (c)	>20/18/15	<u> </u>	 
Emulsified Water	scalar	*Visual	>0.1	<b>6.2%</b>	 

Customer Id: WESLONWC Sample No.: WCI2335370 Lab Number: 04812120 Test Package: IND 2



To manage this report scan the QR code

*To discuss the diagnosis or test data:* Don Baldridge +1 <u>don.b505@comcast.net</u>

*To change component or sample information:* Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>

RECOMMENDED A	IMENDED ACTIONS					
Action	Status	Date	Done By	Description		
Change Filter	MISSED	Jan 16 2020	?	We recommend you service the filters on this component.		
Water Drain-off	MISSED	Jan 16 2020	?	We advise that you follow the water drain-off procedure for this component.		

HISTORICAL DIAGNOSIS



# **OIL ANALYSIS REPORT**

## [10664528] Machine Id INGERSOLL RAND SSR-UP6-30-125 100 C-1 (S/N CBV231518)

Component Compressor

Fluid COMPRESSOR OIL (PAG) ISO 46 (--- GAL)

#### DIAGNOSIS

#### Recommendation

We advise that you follow the water drain-off procedure for this component. We recommend you service the filters on this component. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is a high amount of particulates present in the oil. There is a moderate concentration of water present in the oil.

#### **Fluid Condition**

The AN level is acceptable for this fluid.

				Sep2019		
SAMPLE INFORM	MATION	method	limit/base	current	history 1	history 2
Sample Number		Client Info		WCI2335370		
Sample Date		Client Info		18 Sep 2019		
Machine Age	hrs	Client Info		14352		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				ABNORMAL		
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	1		
Chromium	ppm	ASTM D5185m	>5	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>15	0		
Lead	ppm	ASTM D5185m	>65	<1		
Copper	ppm	ASTM D5185m	>65	4		
Tin	ppm	ASTM D5185m	>10	<1		
Antimony	ppm	ASTM D5185m		<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m	2	4		
Barium	ppm	ASTM D5185m	525	532		
Molybdenum	ppm	ASTM D5185m	10	0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m	5	0		
Calcium	ppm	ASTM D5185m	10	4		
Phosphorus	ppm	ASTM D5185m	250	<1		
Zinc	ppm	ASTM D5185m	100	49		
Sulfur	ppm	ASTM D5185m	400	207		
CONTAMINANTS	6	method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>35	2		
Sodium	ppm	ASTM D5185m		23		
Potassium	ppm	ASTM D5185m	>20	3		
Water	%	ASTM D6304	>0.1	<u> </u>		
ppm Water	ppm	ASTM D6304	>1000	<b>6</b> 5500		
FLUID CLEANLIN	IESS	method	limit/base	current	history 1	history 2
Particles >4µm		ASTM D7647	>10000	<b>44863</b>		
Particles >6µm		ASTM D7647	>2500	<u> </u>		
Particles >14µm		ASTM D7647	>320	<b>6</b> 593		
Particles >21µm		ASTM D7647	>80	<u> </u>		
Particles >38µm		ASTM D7647	>20	8		
Particles >71µm		ASTM D7647		4		
Oil Cleanliness		ISO 4406 (c)	>20/18/15	<b>A</b> 23/21/16		
FLUID DEGRADA	ATION	method	limit/base	current	history 1	history 2
A aid Number (ANI)	ma 1/011/-			0.044		

Acid Number (AN) mg KOH/g ASTM D8045

0.244

Contact/Location: ROB WALLIN - WESLONWC

Report Id: WESLONWC [WUSCAR] 04812120 (Generated: 07/05/2023 08:51:10) Rev: 1

Sample Rating Trend







# **OIL ANALYSIS REPORT**









To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

T: (903)242-7576

F: (903)758-9521