



PROBLEM SUMMARY



KAESER C-706 (S/N 1031)

Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS						
Sample Status		ABNORMA	L ABNORMAL	ATTENTION		
Particles >6µm	ASTM D7647 >1	300 A 2624	956	1 387		
Particles >14µm	ASTM D7647 >8	30 🔺 196	1 63	4 94		
Particles >21µm	ASTM D7647 >2	20 62	▲ 55	<u> </u>		
Particles >38µm	ASTM D7647 >4	- 🔺 5	<u> 8 </u>	1		
Oil Cleanliness	ISO 4406 (c) >-	-/17/13 🔺 21/19/15	18/17/15	2 0/18/14		

Customer Id: WESLONWC Sample No.: WC0390909 Lab Number: 04885979 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS						
Action	Status	Date	Done By	Description		
Change Filter	MISSED	May 21 2020	?	We recommend you service the filters on this component.		

HISTORICAL DIAGNOSIS

23 Sep 2019 Diag: Don Baldridge




We recommend you service the filters on this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid.

view report

18 Jun 2019 Diag: Jonathan Hester









29 Mar 2019 Diag: Jonathan Hester

this fluid.


We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. Appearance is hazy. There is a light concentration of water present in the oil. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.







OIL ANALYSIS REPORT



history 1

current

Machine Id KAESER C-706 (S/N 1031) Component

Compressor Fluid

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


Sample Number						
		Client Info		WC0390909	WCI2335364	WC0475335
Sample Date		Client Info		08 Jan 2020	23 Sep 2019	18 Jun 2019
Machine Age	hrs	Client Info		25619	0	20612
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		Not Changd	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ATTENTION
÷	_					
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	<1	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	<1	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	<1	<1
Lead	ppm	ASTM D5185m	>10	<1	0	<1
Copper	ppm	ASTM D5185m	>50	6	8	<1
Tin	ppm	ASTM D5185m	>10	0	<1	0
Antimony	ppm	ASTM D5185m		0	0	0
Vanadium	ppm	ASTM D5185m		0	0	<1
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history 1	history 2
			IIIII/base			
Boron	ppm	ASTM D5185m		0	<1	4
Barium	ppm	ASTM D5185m	90	2	4	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	90	0	0	<1
Calcium	ppm	ASTM D5185m	2	0	0	<1
Phosphorus	ppm	ASTM D5185m		3	<1	7 30
Zinc	ppm	ASTM D5185m		0	0	5
Sulfur	ppm	ASTM D5185m		12137	9792	▲ 4
CONTAMINANTS	\$	method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	<1	<1	5
Sodium	ppm	ASTM D5185m		0	<1	2
Potassium	ppm	ASTM D5185m	>20	<1	<1	0
FLUID CLEANLIN	IESS	method	limit/base	current	history 1	history 2
	IESS	method ASTM D7647	limit/base		history 1 1756	history 2 6541
Particles >4µm	IESS	ASTM D7647		15003	1756	6541
Particles >4µm Particles >6µm	IESS			15003 ▲ 2624	1756 956	
Particles >4μm Particles >6μm Particles >14μm	JESS	ASTM D7647 ASTM D7647 ASTM D7647	>1300 >80	15003 2624 196	1756 956 ▲ 163	6541 1387 94
Particles >4μm Particles >6μm Particles >14μm Particles >21μm	JESS	ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647	>1300 >80	15003 2624 196 62	1756 956 ▲ 163 ▲ 55	6541 1 387
Particles >4µm Particles >6µm Particles >14µm Particles >21µm Particles >38µm	JESS	ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647	>1300 >80 >20 >4	15003 ▲ 2624 ▲ 196 ▲ 62 ▲ 5	1756 956 ▲ 163 ▲ 55 ▲ 8	6541 ▲ 1387 ▲ 94 ▲ 23 1
Particles >4μm Particles >6μm Particles >14μm Particles >21μm	JESS	ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647	>1300 >80 >20 >4	15003 2624 196 62	1756 956 ▲ 163 ▲ 55	6541 1387 94 23
Particles >4µm Particles >6µm Particles >14µm Particles >21µm Particles >38µm Particles >71µm Oil Cleanliness		ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647 ISO 4406 (c)	>1300 >80 >20 >4 >3 >/17/13	15003 ▲ 2624 ▲ 196 ▲ 62 ▲ 5 0 ▲ 21/19/15	1756 956 ▲ 163 ▲ 55 ▲ 8 0 ▲ 18/17/15	 1387 94 23 1 0 20/18/14
Particles >4µm Particles >6µm Particles >14µm Particles >21µm Particles >38µm Particles >71µm		ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647	>1300 >80 >20 >4 >3	15003 ▲ 2624 ▲ 196 ▲ 62 ▲ 5 0	1756 956 ▲ 163 ▲ 55 ▲ 8 0	6541 ▲ 1387 ▲ 94 ▲ 23 1 0


limit/base



OIL ANALYSIS REPORT







Base

lun16/16

Jan 24/18

4(

30


Й

Jun26/15

Jan 25/16

VISUAL		method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	0.2%	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	46	44.1	43.8	▲ 81.11
SAMPLE IMAGES	;	method	limit/base	current	history 1	history 2
Color						

Bottom



To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Contact/Location: ROB WALLIN - WESLONWC

rwallin@westlake.com

T: (903)242-7576

F: (903)758-9521