

COOLANT REPORT

Area [198984] 0408912 0408912

Component Coolant

Fluid
HYBRID (HOAT) COOLANT (--- GAL)

Sample Rating Trend



Recommendation

The fluid is suitable for further service.

Contaminants

There is no indication of any contamination in the coolant.

Coolant Condition


Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0408912		
Sample Date		Client Info		17 Apr 2020		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
PHYSICAL TEST R	ESULTS	method	limit/base	current	history1	history2
рН	Scale 0-14	ASTM D1287		7.51		
Nitrites	ppm	AP-053:2009		1088		
Reserve Alkalinity	Scale 0-20	*ASTM D1121				
Percentage Glycol	%	ASTM D3321		63		
Freezing Point	°F	ASTM D3321		-77		
Total Dissolved Solids				626.5		
Carboxylate				n/a		
VISUAL		method	limit/base	current	history1	history2
Coolant Color		*Visual		Yllow		
Coolant Appearance		*Visual	Clear	normal		
Color					no image	no image
Bottom					no image	no image



COOLANT REPORT







Laboratory Sample No.

Lab Number : 04964434

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : WC0408912

Received **Tested** Unique Number : 9009575 Diagnosed

: 29 Apr 2020

: 29 Apr 2020 - Doug Bogart

: 28 Apr 2020

Test Package : COOL- (Additional Tests: COOL) Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369. Contact: ANDREW RANDALL andrew.randall@natpow.com T: (919)790-1672

NATIONAL POWER CORP

4541 PRESLYN DR

RALEIGH, NC

US 27616

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (919)790-9714 Contact/Location: ANDREW RANDALL - NATRAL