


PROBLEM SUMMARY

Area
SWEETWATER
Machine Id
D092


Component
Wind Turbine Gearbox
Fluid
MITSUBISHI Daphne Alpha Winforce (60 GAL)

Sample Rating Trend



COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil.

PROBLEMATIC TEST RESULTS

Sample Status		ABNORMAL	ABNORMAL	ABNORMAL
Particles >6µm	ASTM D7647 >5000	▲ 15701	▲ 47353	▲ 8774
Oil Cleanliness	ISO 4406 (c) >--/19/16	▲ 24/21/16	▲ 24/23/17	▲ 22/20/16

Customer Id: MITROS
Sample No.: MHI018342
Lab Number: 04984694
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil.
Resample	---	---	?	Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil.

HISTORICAL DIAGNOSIS

23 Mar 2020 Diag: Don Baldrige

ISO



Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid.

view report



06 Nov 2019 Diag: Don Baldrige

ISO



Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid.

view report



01 Oct 2018 Diag: Don Baldrige

ISO




Re-sample to verify the actual oil condition. Replace filter elements. Change oil if cleanliness level does not improve after replacing the filter(s). All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid.

view report



OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
SWEETWATER
 Machine Id
D092
 Component
Wind Turbine Gearbox
 Fluid
mitsubishi Daphne Alpha Winforce (60 GAL)

DIAGNOSIS

Recommendation

Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil.

Wear

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		MHI018342	MHI018358	MHI188252
Sample Date	Client Info		12 May 2020	23 Mar 2020	06 Nov 2019
Machine Age	hrs	Client Info	0	0	32130
Oil Age	hrs	Client Info	36206	35096	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2	
PQ	ASTM D8184	>200	28	47	13	
Iron	ppm	ASTM D5185m	>200	37	42	24
Chromium	ppm	ASTM D5185m		<1	<1	<1
Nickel	ppm	ASTM D5185m		0	<1	2
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m		0	<1	<1
Lead	ppm	ASTM D5185m		0	0	<1
Copper	ppm	ASTM D5185m	>75	8	7	8
Tin	ppm	ASTM D5185m		<1	<1	0
Antimony	ppm	ASTM D5185m		0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		<1	<1	<1
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		4	4	3
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m		<1	<1	0
Calcium	ppm	ASTM D5185m		1	1	<1
Phosphorus	ppm	ASTM D5185m		374	389	307
Zinc	ppm	ASTM D5185m		0	0	38
Sulfur	ppm	ASTM D5185m		4863	5253	3987

CONTAMINANTS


	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>+30	3	5	3
Sodium	ppm	ASTM D5185m		0	0	<1
Potassium	ppm	ASTM D5185m	>20	0	<1	6
Water	%	ASTM D6304	>0.1	0.009	0.010	0.012
ppm Water	ppm	ASTM D6304	>1000	94.7	106.0	127.5

FLUID CLEANLINESS


	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		88747	143419	35455
Particles >6µm	ASTM D7647	>5000	▲ 15701	▲ 47353	▲ 8774
Particles >14µm	ASTM D7647	>640	424	▲ 1255	538
Particles >21µm	ASTM D7647	>160	66	▲ 149	130
Particles >38µm	ASTM D7647	>40	8	▲ 10	12
Particles >71µm	ASTM D7647	>10	5	▲ 7	0
Oil Cleanliness	ISO 4406 (c)	>--/19/16	▲ 24/21/16	▲ 24/23/17	▲ 22/20/16

OIL ANALYSIS REPORT


Particle Trend




Water (KF)




PQ



Water (KF)



Viscosity @ 40°C



FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		1.117	1.137	1.247


VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	MODER	MODER	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445		325	340	326

SAMPLE IMAGES


Color

Bottom




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : MHI018342 Received : 26 May 2020
 Lab Number : 04984694 Diagnosed : 28 May 2020
 Unique Number : 9039841 Diagnostician : Don Baldrige
 Test Package : IND 2 (Additional Tests: KF, PQ, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

DIAMOND WTG - SWEETWATER SITE - MPS SW
 7900 FM 608
 ROSCOE, TX
 US 79545

Contact: MATTHEW MILES
 matthew.miles@diamondwtg.com

T: (325)288-4333
 F: (325)288-4338