


# PROBLEM SUMMARY

Sample Rating Trend



**VIS DEBRIS**



Machine Id  
**A-48**  
Component  
**Wind Turbine Gearbox**  
Fluid  
**MITSUBISHI Daphne Alpha Winforce (--- LTR)**

## COMPONENT CONDITION SUMMARY

No relevant graphs to display

## RECOMMENDATION

Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil. We were unable to perform a particle count due to a high concentration of particles present in this sample.

## PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	NORMAL
Debris	scalar	*Visual	NONE	<b>▲ MODER</b>	LIGHT	NONE

**Customer Id:** MITSANM  
**Sample No.:** MHI023579  
**Lab Number:** 05000025  
**Test Package:** IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Doug Bogart +1 (800)237-1369 x4016  
[dougb@wearcheckusa.com](mailto:dougb@wearcheckusa.com)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil.
Resample	---	---	?	Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil.
Alert	---	---	?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

## HISTORICAL DIAGNOSIS

### 02 Dec 2019 Diag: Don Baldrige

ISO



Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

view report



### 12 Dec 2018 Diag: Don Baldrige

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 07 Nov 2017 Diag: Wes Davis

NORMAL




Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



# OIL ANALYSIS REPORT

## Sample Rating Trend



## VIS DEBRIS



Machine Id

**A-48**

Component

**Wind Turbine Gearbox**

Fluid

**MTSUBISHI Daphne Alpha Winforce (--- LTR)**

### DIAGNOSIS

#### ▲ Recommendation

Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil. We were unable to perform a particle count due to a high concentration of particles present in this sample.

#### Wear

All component wear rates are normal.

#### ▲ Contamination

Moderate concentration of visible dirt/debris present in the oil.

#### Fluid Condition

The AN level is acceptable for this fluid.

### SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>MHI023579</b>	MHI019006	MHI020397
Sample Date	Client Info	<b>01 Jun 2020</b>	02 Dec 2019	12 Dec 2018
Machine Age	hrs	<b>0</b>	0	84910
Oil Age	hrs	<b>95865</b>	92053	0
Oil Changed	Client Info	<b>Not Chngd</b>	Not Chngd	Not Chngd
Sample Status		<b>ABNORMAL</b>	ABNORMAL	NORMAL

### WEAR METALS

method	limit/base	current	history1	history2		
PQ	ASTM D8184	>200	<b>17</b>	15	21	
Iron	ppm	ASTM D5185m	>200	<b>32</b>	30	26
Chromium	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Nickel	ppm	ASTM D5185m		<b>0</b>	<1	<1
Titanium	ppm	ASTM D5185m		<b>0</b>	0	0
Silver	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Aluminum	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Lead	ppm	ASTM D5185m		<b>0</b>	0	0
Copper	ppm	ASTM D5185m	>75	<b>10</b>	9	7
Tin	ppm	ASTM D5185m		<b>0</b>	<1	<1
Antimony	ppm	ASTM D5185m		<b>4</b>	0	0
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0

### ADDITIVES

method	limit/base	current	history1	history2		
Boron	ppm	ASTM D5185m		<b>1</b>	<1	<1
Barium	ppm	ASTM D5185m		<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m		<b>0</b>	<1	<1
Manganese	ppm	ASTM D5185m		<b>1</b>	<1	<1
Magnesium	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Calcium	ppm	ASTM D5185m		<b>0</b>	0	0
Phosphorus	ppm	ASTM D5185m		<b>300</b>	329	357
Zinc	ppm	ASTM D5185m		<b>32</b>	19	23
Sulfur	ppm	ASTM D5185m		<b>3683</b>	4419	4044





### CONTAMINANTS

method	limit/base	current	history1	history2		
Silicon	ppm	ASTM D5185m	>+30	<b>&lt;1</b>	2	1
Sodium	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Potassium	ppm	ASTM D5185m	>20	<b>&lt;1</b>	<1	<1
Water	%	ASTM D6304	>0.1	<b>0.010</b>	0.006	0.007
ppm Water	ppm	ASTM D6304	>1000	<b>109.2</b>	68.2	70

### FLUID CLEANLINESS

method	limit/base	current	history1	history2	
Particles >4µm	ASTM D7647		---	51878	807
Particles >6µm	ASTM D7647	>5000	---	▲ 8021	440
Particles >14µm	ASTM D7647	>640	---	620	74
Particles >21µm	ASTM D7647	>160	---	179	25
Particles >38µm	ASTM D7647	>40	---	8	3
Particles >71µm	ASTM D7647	>10	---	0	0
Oil Cleanliness	ISO 4406 (c)	>--/19/16	---	▲ 23/20/16	17/16/13

# OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>0.779</b>	0.788	0.900





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	*Visual	NONE	<b>▲ MODER</b>	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	<b>NEG</b>	NEG	NEG
Free Water	scalar	*Visual		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445		<b>325</b>	322	322.0

### SAMPLE IMAGES



### GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : MH1023579 **Received** : 16 Jun 2020  
**Lab Number** : 05000025 **Diagnosed** : 19 Jun 2020  
**Unique Number** : 9065178 **Diagnostician** : Doug Bogart  
**Test Package** : IND 2 ( Additional Tests: KF, PQ, PrtCount )

**DIAMOND WTG - ARAGONNE MESA SITE - MPS AM**  
 PO BOX 372  
 SANTA ROSA, NM  
 US 88435  
 Contact: BOBBY VILLANUEVA  
 bobby.villanueva@diamondwtg.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)