


# PROBLEM SUMMARY

Sample Rating Trend




ISO



Machine Id  
**A-27**  
Component  
**Wind Turbine Gearbox**  
Fluid  
**MITSUBISHI Daphne Alpha Winforce (--- LTR)**

## COMPONENT CONDITION SUMMARY

▲ Particle Trend



## RECOMMENDATION

Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil.

## PROBLEMATIC TEST RESULTS

Sample Status		ABNORMAL	ABNORMAL	NORMAL
Particles >6µm	ASTM D7647 >5000	▲ 6948	▲ 20877	685
Oil Cleanliness	ISO 4406 (c) >--/19/16	▲ 22/20/16	▲ 23/22/17	19/17/12

Customer Id: MITSANNM  
Sample No.: MHI023565  
Lab Number: 05018370  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Don Baldrige +1  
[don.b505@comcast.net](mailto:don.b505@comcast.net)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil.
Resample	---	---	?	Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil.

## HISTORICAL DIAGNOSIS

### 09 Jan 2020 Diag: Doug Bogart

ISO



Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid.

view report



### 11 Dec 2019 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 09 Oct 2019 Diag: Don Baldrige

ISO




Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid.

view report



# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id  
**A-27**  
 Component  
**Wind Turbine Gearbox**  
 Fluid  
**mitsubishi Daphne Alpha Winforce (--- LTR)**

## DIAGNOSIS

### Recommendation

Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil.

### Wear

All component wear rates are normal.

### Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>MHI023565</b>	MHI018583	MHI018545
Sample Date	Client Info			<b>01 Jul 2020</b>	09 Jan 2020	11 Dec 2019
Machine Age	hrs	Client Info		<b>0</b>	0	0
Oil Age	hrs	Client Info		<b>88853</b>	85217	84583
Oil Changed	Client Info			<b>Not Chngd</b>	Not Chngd	Not Chngd
Sample Status				<b>ABNORMAL</b>	ABNORMAL	NORMAL






WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184	>200	<b>17</b>	16	18
Iron	ppm	ASTM D5185m	>200	<b>40</b>	43	35
Chromium	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Nickel	ppm	ASTM D5185m		<b>0</b>	<1	0
Titanium	ppm	ASTM D5185m		<b>0</b>	0	0
Silver	ppm	ASTM D5185m		<b>0</b>	<1	0
Aluminum	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Lead	ppm	ASTM D5185m		<b>0</b>	0	0
Copper	ppm	ASTM D5185m	>75	<b>10</b>	8	7
Tin	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Antimony	ppm	ASTM D5185m		<b>0</b>	0	0
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Barium	ppm	ASTM D5185m		<b>0</b>	<1	<1
Molybdenum	ppm	ASTM D5185m		<b>&lt;1</b>	1	<1
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185m		<b>0</b>	2	0
Calcium	ppm	ASTM D5185m		<b>0</b>	<1	1
Phosphorus	ppm	ASTM D5185m		<b>335</b>	377	347
Zinc	ppm	ASTM D5185m		<b>0</b>	0	2
Sulfur	ppm	ASTM D5185m		<b>4632</b>	4838	4412

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>+30	<b>5</b>	2	4
Sodium	ppm	ASTM D5185m		<b>0</b>	2	<1
Potassium	ppm	ASTM D5185m	>20	<b>&lt;1</b>	<1	<1
Water	%	ASTM D6304	>0.1	<b>0.007</b>	0.006	0.007
ppm Water	ppm	ASTM D6304	>1000	<b>71.0</b>	63.3	77.9

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		<b>26160</b>	78120	3982
Particles >6µm		ASTM D7647	>5000	<b>▲ 6948</b>	▲ 20877	685
Particles >14µm		ASTM D7647	>640	<b>487</b>	▲ 900	31
Particles >21µm		ASTM D7647	>160	<b>114</b>	▲ 185	6
Particles >38µm		ASTM D7647	>40	<b>4</b>	5	0
Particles >71µm		ASTM D7647	>10	<b>0</b>	0	0
Oil Cleanliness		ISO 4406 (c)	>--/19/16	<b>▲ 22/20/16</b>	▲ 23/22/17	19/17/12

# OIL ANALYSIS REPORT




FLUID DEGRADATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.878</b>	0.881	0.950






VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	<b>327</b>	327	325

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : MHI023565 **Received** : 13 Jul 2020  
**Lab Number** : 05018370 **Diagnosed** : 14 Jul 2020  
**Unique Number** : 9098530 **Diagnostician** : Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: KF, PQ, PrtCount )

**DIAMOND WTG - ARAGONNE MESA SITE - MPS AM**  
 PO BOX 372  
 SANTA ROSA, NM  
 US 88435  
 Contact: BOBBY VILLANUEVA  
 bobby.villanueva@diamondwtg.com  
 T: x:  
 F: x: