


# PROBLEM SUMMARY

## Sample Rating Trend




ISO



Machine Id  
**A-23**  
Component  
**Hydraulic System**  
Fluid  
**MOBIL DTE 10 EXCEL 32 (165 LTR)**

## COMPONENT CONDITION SUMMARY

### ▲ Particle Trend



## RECOMMENDATION

Re-sample to verify the actual oil condition. Replace filter elements. Change oil if cleanliness level does not improve after replacing the filter(s).

## PROBLEMATIC TEST RESULTS

Sample Status		<b>ABNORMAL</b>	ABNORMAL	NORMAL
Particles >6µm	ASTM D7647 >1300	▲ <b>1455</b>	▲ 2531	255
Oil Cleanliness	ISO 4406 (c) >19/17/14	▲ <b>19/18/14</b>	▲ 21/19/14	17/15/12

Customer Id: MITSANM  
Sample No.: MHI023554  
Lab Number: 05023609  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Don Baldrige +1  
[don.b505@comcast.net](mailto:don.b505@comcast.net)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	Re-sample to verify the actual oil condition. Replace filter elements. Change oil if cleanliness level does not improve after replacing the filter(s).
Resample	---	---	?	Re-sample to verify the actual oil condition. Replace filter elements. Change oil if cleanliness level does not improve after replacing the filter(s).

## HISTORICAL DIAGNOSIS

### 15 Jan 2020 Diag: Doug Bogart

ISO



Re-sample to verify the actual oil condition. Replace filter elements. Change oil if cleanliness level does not improve after replacing the filter(s). All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid.

view report



### 07 Oct 2019 Diag: Don Baldrige

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 12 Mar 2019 Diag: Don Baldrige

NORMAL




Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id  
**A-23**  
 Component  
**Hydraulic System**  
 Fluid  
**MOBIL DTE 10 EXCEL 32 (165 LTR)**

## DIAGNOSIS

### Recommendation

Re-sample to verify the actual oil condition. Replace filter elements. Change oil if cleanliness level does not improve after replacing the filter(s).

### Wear

All component wear rates are normal.

### Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>MHI023554</b>	MHI018518	MHI04826145
Sample Date	Client Info			<b>09 Jul 2020</b>	15 Jan 2020	07 Oct 2019
Machine Age	hrs	Client Info		<b>0</b>	0	0
Oil Age	hrs	Client Info		<b>95360</b>	91747	0
Oil Changed	Client Info			<b>Not Chngd</b>	Not Chngd	N/A
Sample Status				<b>ABNORMAL</b>	ABNORMAL	NORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<b>3</b>	4	4
Chromium	ppm	ASTM D5185m		<b>0</b>	0	<1
Nickel	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Titanium	ppm	ASTM D5185m		<b>0</b>	0	0
Silver	ppm	ASTM D5185m		<b>0</b>	<1	0
Aluminum	ppm	ASTM D5185m		<b>0</b>	0	<1
Lead	ppm	ASTM D5185m		<b>&lt;1</b>	1	4
Copper	ppm	ASTM D5185m		<b>&lt;1</b>	2	<1
Tin	ppm	ASTM D5185m		<b>0</b>	<1	0
Antimony	ppm	ASTM D5185m		<b>0</b>	0	0
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<b>&lt;1</b>	<1	0
Barium	ppm	ASTM D5185m		<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m		<b>0</b>	0	<1
Manganese	ppm	ASTM D5185m		<b>0</b>	0	<1
Magnesium	ppm	ASTM D5185m		<b>&lt;1</b>	<1	0
Calcium	ppm	ASTM D5185m		<b>92</b>	113	134
Phosphorus	ppm	ASTM D5185m		<b>419</b>	475	532
Zinc	ppm	ASTM D5185m		<b>32</b>	40	24
Sulfur	ppm	ASTM D5185m		<b>1287</b>	1335	808


CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>+30	<b>3</b>	1	0
Sodium	ppm	ASTM D5185m		<b>0</b>	2	2
Potassium	ppm	ASTM D5185m	>20	<b>0</b>	<1	0
Water	%	ASTM D6304	>0.1	<b>0.004</b>	0.003	0.004
ppm Water	ppm	ASTM D6304	>1000	<b>45.8</b>	37.9	43.3

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	<b>4839</b>	▲ 10364	797
Particles >6µm		ASTM D7647	>1300	▲ <b>1455</b>	▲ 2531	255
Particles >14µm		ASTM D7647	>160	<b>124</b>	116	32
Particles >21µm		ASTM D7647	>40	<b>27</b>	34	6
Particles >38µm		ASTM D7647	>10	<b>0</b>	4	0
Particles >71µm		ASTM D7647	>3	<b>0</b>	1	0
Oil Cleanliness		ISO 4406 (c)	>19/17/14	▲ <b>19/18/14</b>	▲ 21/19/14	17/15/12


FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>0.14</b>	0.106	0.107

# OIL ANALYSIS REPORT


## Particle Trend




## Water




## Acid Number



## Water



## Viscosity @ 40°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	32.0	31.9	31.3

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color




Bottom




## GRAPHS


### Ferrous Alloys




### Non-ferrous Metals




### Viscosity @ 40°C



### Particle Count



### Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
 Sample No. : MH1023554  
 Lab Number : 05023609  
 Unique Number : 9103769  
 Test Package : IND 2 ( Additional Tests: KF )

DIAMOND WTG - ARAGONNE MESA SITE - MPS AM  
 PO BOX 372  
 SANTA ROSA, NM  
 US 88435  
 Contact: BOBBY VILLANUEVA  
 bobby.villanueva@diamondwtg.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: x  
F: x