




OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
STARCH
 Machine Id
A27P202

Component
Pump
 Fluid
PETRO CANADA PURITY FG HYDRAULIC AW 68 (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0371043	WC0483582	WC0371050
Sample Date	Client Info		28 Jul 2020	16 Jul 2020	01 Jul 2020
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >90	15	14	14
Chromium	ppm	ASTM D5185m	0	0	<1
Nickel	ppm	ASTM D5185m	<1	0	0
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >7	<1	0	0
Lead	ppm	ASTM D5185m >12	1	<1	<1
Copper	ppm	ASTM D5185m >30	3	3	4
Tin	ppm	ASTM D5185m >9	0	0	<1
Antimony	ppm	ASTM D5185m	0	0	0
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	<1
Barium	ppm	ASTM D5185m	<1	0	0
Molybdenum	ppm	ASTM D5185m	<1	0	<1
Manganese	ppm	ASTM D5185m	<1	<1	<1
Magnesium	ppm	ASTM D5185m	<1	0	0
Calcium	ppm	ASTM D5185m	2	<1	4
Phosphorus	ppm	ASTM D5185m	485	462	459
Zinc	ppm	ASTM D5185m	10	6	0
Sulfur	ppm	ASTM D5185m	414	678	442

CONTAMINANTS





	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >60	10	10	8
Sodium	ppm	ASTM D5185m	0	0	0
Potassium	ppm	ASTM D5185m >20	2	<1	<1

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	▲ 73286	▲ 76631	▲ 79217
Particles >6µm	ASTM D7647	>1300	▲ 12672	▲ 15101	▲ 13275
Particles >14µm	ASTM D7647	>160	▲ 237	▲ 246	▲ 399
Particles >21µm	ASTM D7647	>40	▲ 55	38	▲ 66
Particles >38µm	ASTM D7647	>10	4	9	3
Particles >71µm	ASTM D7647	>3	0	2	0
Oil Cleanliness	ISO 4406 (c)	>19/17/14	▲ 23/21/15	▲ 23/21/15	▲ 23/21/16



OIL ANALYSIS REPORT




FLUID DEGRADATION	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.26	0.227	0.249	0.260






VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	NEG	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D445	63.34	66.0	65.6	65.8

SAMPLE IMAGES



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0371043 **Received** : 03 Aug 2020
Lab Number : 05034012 **Diagnosed** : 05 Aug 2020
Unique Number : 9124182 **Diagnostician** : Don Baldrige
Test Package : IND 2 (Additional Tests: PrtCount)

INGREDION - BEDFORD PARK
 6400 SOUTH ARCHER ROAD
 BEDFORD PARK, IL
 US 60501
 Contact: Ricardo Gutierrez
 Ricardo.Gutierrez@ingredion.com
 T: (219)805-1307
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)