


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area
(NCR 6814)

Machine Id
A-01

Component
Wind Turbine Gearbox

Fluid
mitsubishi Daphne Alpha Winforce (--- LTR)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history 1	history 2
Sample Number	Client Info		MHI023610	MHI018566	MHI018513
Sample Date	Client Info		29 Jul 2020	18 Mar 2020	27 Feb 2020
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	98360	95600	95174
Oil Changed	Client Info		Not Changed	Not Changed	Not Changed
Sample Status			NORMAL	NORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history 1	history 2	
PQ	ASTM D8184	>200	20	24	17	
Iron	ppm	ASTM D5185m	>200	59	47	53
Chromium	ppm	ASTM D5185m		0	<1	<1
Nickel	ppm	ASTM D5185m		<1	<1	<1
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m		<1	<1	<1
Aluminum	ppm	ASTM D5185m		0	0	0
Lead	ppm	ASTM D5185m		0	<1	0
Copper	ppm	ASTM D5185m	>75	58	27	31
Tin	ppm	ASTM D5185m		7	1	1
Antimony	ppm	ASTM D5185m		0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0

ADDITIVES

	method	limit/base	current	history 1	history 2	
Boron	ppm	ASTM D5185m		3	<1	<1
Barium	ppm	ASTM D5185m		0	<1	0
Molybdenum	ppm	ASTM D5185m		0	<1	<1
Manganese	ppm	ASTM D5185m		<1	1	1
Magnesium	ppm	ASTM D5185m		0	1	2
Calcium	ppm	ASTM D5185m		0	<1	0
Phosphorus	ppm	ASTM D5185m		310	288	327
Zinc	ppm	ASTM D5185m		62	55	63
Sulfur	ppm	ASTM D5185m		3784	4075	4665






CONTAMINANTS

	method	limit/base	current	history 1	history 2	
Silicon	ppm	ASTM D5185m	>+30	3	3	3
Sodium	ppm	ASTM D5185m		<1	1	<1
Potassium	ppm	ASTM D5185m	>20	0	<1	0
Water	%	ASTM D6304	>0.1	0.027	0.004	0.006
ppm Water	ppm	ASTM D6304	>1000	278.3	44.2	60.9

FLUID CLEANLINESS

	method	limit/base	current	history 1	history 2
Particles >4µm	ASTM D7647		25854	2674	19071
Particles >6µm	ASTM D7647	>5000	1742	667	▲ 5721
Particles >14µm	ASTM D7647	>640	32	50	353
Particles >21µm	ASTM D7647	>160	6	13	70
Particles >38µm	ASTM D7647	>40	0	1	3
Particles >71µm	ASTM D7647	>10	0	0	0
Oil Cleanliness	ISO 4406 (c)	>--/19/16	22/18/12	19/17/13	▲ 21/20/16

OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history 1	history 2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.959	0.926	0.920






VISUAL		method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	VLITE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445		330	331	331

SAMPLE IMAGES		method	limit/base	current	history 1	history 2
---------------	--	--------	------------	---------	-----------	-----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : MH1023610 **Received** : 07 Aug 2020
Lab Number : **05038756** **Diagnosed** : 12 Aug 2020
Unique Number : 9128926 **Diagnostician** : Jonathan Hester
Test Package : IND 2 (Additional Tests: KF, PQ, PrtCount)

DIAMOND WTG - ARAGONNE MESA SITE - MPS AM
 PO BOX 372
 SANTA ROSA, NM
 US 88435
 Contact: BOBBY VILLANUEVA
 bobby.villanueva@diamondwtg.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: x:
F: x: