


PROBLEM SUMMARY

Sample Rating Trend




ISO



Machine Id
A-02
Component
Wind Turbine Gearbox
Fluid
MITSUBISHI Daphne Alpha Winforce (--- LTR)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil.

PROBLEMATIC TEST RESULTS

Sample Status		ABNORMAL	ABNORMAL	ABNORMAL
Particles >6µm	ASTM D7647 >5000	▲ 5917	▲ 5162	▲ 6390
Oil Cleanliness	ISO 4406 (c) >--/19/16	▲ 22/20/15	▲ 22/20/16	▲ 23/20/15

Customer Id: MITSANM
Sample No.: MHI017344
Lab Number: 05047702
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil.
Resample	---	---	?	Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil.

HISTORICAL DIAGNOSIS

18 Mar 2020 Diag: Don Baldrige

ISO



Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil. The oil change at the time of sampling has been noted. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid.

view report



26 Feb 2020 Diag: Don Baldrige

ISO



Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid.

view report



04 Dec 2019 Diag: Don Baldrige

NORMAL




Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id
A-02
Component
Wind Turbine Gearbox
Fluid
mitsubishi Daphne Alpha Winforce (--- LTR)

DIAGNOSIS

Recommendation

Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	MHI017344	MHI018829	MHI018525
Sample Date	Client Info	13 Aug 2020	18 Mar 2020	26 Feb 2020
Machine Age	hrs	0	0	0
Oil Age	hrs	98474	95415	94245
Oil Changed	Client Info	Not Changed	Changed	Not Changed
Sample Status		ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

method	limit/base	current	history1	history2		
PQ	ASTM D8184	>200	15	19	20	
Iron	ppm	ASTM D5185m	>200	22	23	27
Chromium	ppm	ASTM D5185m		<1	<1	<1
Nickel	ppm	ASTM D5185m		4	<1	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	<1	0
Aluminum	ppm	ASTM D5185m		0	0	0
Lead	ppm	ASTM D5185m		<1	<1	0
Copper	ppm	ASTM D5185m	>75	12	9	10
Tin	ppm	ASTM D5185m		<1	<1	<1
Antimony	ppm	ASTM D5185m		0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0

ADDITIVES

method	limit/base	current	history1	history2		
Boron	ppm	ASTM D5185m		2	<1	<1
Barium	ppm	ASTM D5185m		0	<1	0
Molybdenum	ppm	ASTM D5185m		0	<1	<1
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m		<1	<1	<1
Calcium	ppm	ASTM D5185m		0	<1	0
Phosphorus	ppm	ASTM D5185m		318	326	356
Zinc	ppm	ASTM D5185m		61	21	30
Sulfur	ppm	ASTM D5185m		4402	4470	4954






CONTAMINANTS

method	limit/base	current	history1	history2		
Silicon	ppm	ASTM D5185m	>+30	0	2	2
Sodium	ppm	ASTM D5185m		<1	1	<1
Potassium	ppm	ASTM D5185m	>20	0	<1	0
Water	%	ASTM D6304	>0.1	0.008	0.003	0.005
ppm Water	ppm	ASTM D6304	>1000	87.6	28.9	50.6

FLUID CLEANLINESS

method	limit/base	current	history1	history2	
Particles >4µm	ASTM D7647		26007	29783	54684
Particles >6µm	ASTM D7647	>5000	5917	5162	6390
Particles >14µm	ASTM D7647	>640	241	345	310
Particles >21µm	ASTM D7647	>160	47	79	87
Particles >38µm	ASTM D7647	>40	3	2	4
Particles >71µm	ASTM D7647	>10	0	0	0
Oil Cleanliness	ISO 4406 (c)	>--/19/16	22/20/15	22/20/16	23/20/15

OIL ANALYSIS REPORT



FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.930	0.824	0.819


VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE	VLITE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445		321	322	324






SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------

Color

Bottom



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : MHI017344 **Received** : 20 Aug 2020
Lab Number : 05047702 **Diagnosed** : 21 Aug 2020
Unique Number : 9142873 **Diagnostician** : Don Baldrige
Test Package : IND 2 (Additional Tests: KF, PQ, PrtCount)

DIAMOND WTG - ARAGONNE MESA SITE - MPS AM
 PO BOX 372
 SANTA ROSA, NM
 US 88435
 Contact: BOBBY VILLANUEVA
 bobby.villanueva@diamondwtg.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: x:
F: x: