




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
INGERSOLL RAND SSR-UP6-30-125 100 C-1 (S/N CBV231518)

Component
Compressor

Fluid
INGERSOLL-RAND SSR ULTRA COOLANT (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history 1	history 2
Sample Number	Client Info		WCI2335368	WC0390912	WC0390904
Sample Date	Client Info		28 Aug 2020	14 May 2020	12 Jan 2020
Machine Age	hrs	Client Info	22702	20090	16848
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		Not Chngd	N/A	N/A
Sample Status			NORMAL	ABNORMAL	NORMAL

WEAR METALS

	method	limit/base	current	history 1	history 2	
Iron	ppm	ASTM D5185m	>50	2	3	2
Chromium	ppm	ASTM D5185m	>5	0	0	<1
Nickel	ppm	ASTM D5185m		0	<1	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>15	0	0	<1
Lead	ppm	ASTM D5185m	>65	<1	<1	<1
Copper	ppm	ASTM D5185m	>65	4	6	7
Tin	ppm	ASTM D5185m	>10	<1	<1	<1
Antimony	ppm	ASTM D5185m		0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0

ADDITIVES

	method	limit/base	current	history 1	history 2	
Boron	ppm	ASTM D5185m	0	3	<1	3
Barium	ppm	ASTM D5185m	500	587	458	560
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m	0	0	<1	2
Calcium	ppm	ASTM D5185m	0	6	6	9
Phosphorus	ppm	ASTM D5185m	20	3	3	4
Zinc	ppm	ASTM D5185m	0	41	70	55
Sulfur	ppm	ASTM D5185m	200	288	269	547

CONTAMINANTS

	method	limit/base	current	history 1	history 2	
Silicon	ppm	ASTM D5185m	>35	<1	1	1
Sodium	ppm	ASTM D5185m		26	44	33
Potassium	ppm	ASTM D5185m	>20	2	3	2

FLUID CLEANLINESS





	method	limit/base	current	history 1	history 2
Particles >4µm	ASTM D7647	>10000	3678	---	4624
Particles >6µm	ASTM D7647	>2500	832	---	764
Particles >14µm	ASTM D7647	>320	66	---	62
Particles >21µm	ASTM D7647	>80	24	---	18
Particles >38µm	ASTM D7647	>20	2	---	1
Particles >71µm	ASTM D7647	>4	0	---	0
Oil Cleanliness	ISO 4406 (c)	>20/18/15	19/17/13	---	19/17/13

FLUID DEGRADATION

	method	limit/base	current	history 1	history 2	
Acid Number (AN)	mg KOH/g	ASTM D8045		0.249	0.409	0.266



OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	0.2%
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history 1	history 2	
Visc @ 40°C	cSt	ASTM D445	49.4	51.2	50.9	50.4

SAMPLE IMAGES	method	limit/base	current	history 1	history 2
Color					
Bottom					

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC12335368 **Received** : 04 Sep 2020
Lab Number : 05059535 **Diagnosed** : 09 Sep 2020
Unique Number : 9164716 **Diagnostician** : Doug Bogart
Test Package : IND 2 (Additional Tests: PrtCount)

WESTLAKE CHEMICAL
 2290 CALLAHAN RD
 LONGVIEW, TX
 US 75607
 Contact: ROB WALLIN
 rwallin@westlake.com
 T: (903)242-7576
 F: (903)758-9521

Certificate L2367
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)