


Machine Id **E013** Component **Wind Turbine Gearbox** Fluid **MITSUBISHI Daphne Alpha Winforce (60 GAL)**

COMPONENT CONDITION SUMMARY



RECOMMENDATION

Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil.

PROBLEMATIC TEST RESULTS								
Sample Status		ABNORMAL	ABNORMAL	ABNORMAL				
Particles >6µm	ASTM D7647 >500	0 🔺 9546	1 1085	405				
Particles >14µm	ASTM D7647 >640) 🔺 732	219	69				
Particles >21µm	ASTM D7647 >160) 🔺 195	42	23				
Oil Cleanliness	ISO 4406 (c) >/1	9/16 🔺 23/20/17	🔺 24/21/15	17/16/13				

Customer Id: MITROS Sample No.: MHI025258 Lab Number: 05073860 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Don Baldridge +1 <u>don.b505@comcast.net</u>

To change component or sample information: Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>

RECOMMENDE	O ACTIONS			
Action	Status	Date	Done By	Description
Change Filter			?	Replace filter elem and cleanliness wa
Resample			?	Replace filter elem and cleanliness wa

place filter element and resample at later date. In case already attempted cleanliness was not improved then proceed to replace oil.

Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil.

HISTORICAL DIAGNOSIS



27 Mar 2019 Diag: Jonathan Hester

Re-sample to verify the actual oil condition. Replace filter elements. Change oil if cleanliness level does not improve after replacing the filter(s).All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid.



view report

14 Jun 2013 Diag: Jonathan Hester



We advise that you check all areas where dirt can enter the system. Resample at the next service interval to monitor.All component wear rates are normal. Elemental levels of silicon (Si) and aluminum (Al) indicate aluminasilicate (coarse dirt) ingress. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

14 Jun 2013 Diag: Jonathan Hester






Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT





Machine Id **E013** Component Wind Turbine Gearbox

Fluid MITSUBISHI Daphne Alpha Winforce (60 GAL)

DIAGNOSIS

Recommendation

Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info	MHI025258		MHI188174	RP160149
Sample Date		Client Info	16 Sep 2020		27 Mar 2019	14 Jun 2013
Machine Age	hrs	Client Info	0		88602	47436
Oil Age	hrs	Client Info	100247		0	47436
Oil Changed		Client Info		N/A	Not Changd	Not Changd
Sample Status			ABNORMAL		ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184	>200	16	15	18.0
Iron	ppm	ASTM D5185m	>200	18	12	49
Chromium	ppm	ASTM D5185m		<1	<1	<1
Nickel	ppm	ASTM D5185m		<1	<1	<1
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m		0	0	▲ 12
Lead	ppm	ASTM D5185m		1	0	<1
Copper	ppm		>75	9	5	<1
Tin	ppm	ASTM D5185m		0	0	0
Antimony	ppm	ASTM D5185m		0	<1	16
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		ء <1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		2	<1	68
Barium	ppm	ASTM D5185m		0	0	4
Molybdenum	ppm	ASTM D5185m		2	2	10
Manganese	ppm	ASTM D5185m		<1	0	3
Magnesium	ppm	ASTM D5185m		0	0	<1
Calcium	ppm	ASTM D5185m		<1	<1	2
Phosphorus	ppm	ASTM D5185m		280	233	419
Zinc	ppm	ASTM D5185m		3	15	103
Sulfur	ppm	ASTM D5185m		4096	3956	13784
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>+30	4	0	3 0
Sodium	ppm	ASTM D5185m		<1	1	<1
Potassium	ppm	ASTM D5185m	>20	3	<1	1
Water	%	ASTM D6304	>0.1	0.004	0.006	0.020
ppm Water	ppm	ASTM D6304	>1000	43.3	60	200
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		45607	81493	743
Particles >6µm		ASTM D7647	>5000	<u> </u>	▲ 11085	405
Particles >14µm		ASTM D7647	>640	7 32	219	69
Particles >21µm		ASTM D7647		195	42	23
Particles >38µm		ASTM D7647	>40	6	1	3
Particles >71µm		ASTM D7647		0	0	0
Oil Cleanliness		ISO 4406 (c)	>/19/16	▲ 23/20/17	A 24/21/15	17/16/13
						17,10,10



OIL ANALYSIS REPORT

A Particle Trend			FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
4μm			Acid Number (AN)	mg KOH/g	ASTM D8045		0.928	0.769	0.490
80k μm 80g 60k 9 60k 9 60k 9 60k 9 20k			VISUAL		method	limit/base	current	history1	history2
5 40k -	/	\sim	White Metal	scalar	*Visual	NONE	NONE	VLITE	NONE
20k -			Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
			Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
0k 11/8	4/13	Mar27/19	Silt	scalar	*Visual	NONE	NONE	NONE	NONE
May16/11	Jun14/13	Mar27/19 Sep16/20	Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Water (KF)			Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
12000			Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
10000 - Severe			Odor Emulsified Water	scalar	*Visual *Visual	NORML	NORML	NORML NEG	NORML NEG
8000 - 6000 - 4000 -			Free Water	scalar scalar	*Visual	>0.1	NEG NEG	NEG	NEG
4000 -			FLUID PROPERT	FIES	method	limit/base	current	history1	history2
2000 - Abnormal			Visc @ 40°C	cSt	ASTM D445		319	314.5	186.0
May16/11	Jun14/13	Mar27/19 - Sep16/20 -	SAMPLE IMAGE	S	method	limit/base	current	history1	history2
PQ 400 350 - Severe		Na Sej	Color						no image
300 - 250 - ₽ 200 - Abnormal 150 - 100 -			Bottom						no image
50			GRAPHS						
May16/11 Jun14/13	Jun 14/13	Mar27/19 Sep16/20	Ferrous Alloys			491,520	Particle Count		T 26
IM IL	٦r	Mi	iron						
Water (KF)			40 - mickel			122,880			-24
12000 10000 Severe	1		20-		~~~	30,720			-22
8000			3 J	13	- 61/	080,7 E 7,680		•	-20 2
6000			May16/11	Jun14/13	Mar27/19	02/91 des (ber 1 ml) 480			-20 50 440 1933 -18 10 1933 -16 1933 -17 1934 -17 1934 -1
4000-			Non-ferrous Meta						-16 2
2000 Abnormal			10 copper			120			-14
0			E 5-		\checkmark	-Gun 30			-12
May16/11 Jun14/13	Jun 14/13	Mar27/19							
M JU	- Pr	M	0		CO.		Sebrea email		10
Viscosity @ 40°	°C		May16/1	Jun 14/13	Mar27/19	Sep16/20	•		
0			≊ ⊰ Viscosity @ 40°C	Ju	Ξ	8 0 4		14µ 21µ	38µ 71µ
350			400 Abnormal			\$6.0	Acid Number		
300 Abnormal		0	350			9 2 40	Severe		
3 250 - Abnormal		cSt (40°C)	250 Abnormal		/	4.0 4.0 Winnber 2.0 0.0	Abnomia	1	
200 -	\checkmark	3	200			2.0 N p			
150				H13+	+ 61//	0.0 H	6/11-	M13	//19-
May16/11	un14/13	Mar27/19	May16/11	Jun14/13	Mar27/19	Sep16/20	May16/11 Jun14/13	Jun14/13	Mar27/19 Sep16/20
	Certificate 12367 To discuss this * - Denotes tes	Laboratory Sample No. Lab Number Unique Number Test Package sample report, of t methods that au	: 05073860	Received Diagnost Diagnost ests: KF, ice at 1-8 7025 sco	l : 25 \$ ed : 28 \$ ician : Dor PQ, PrtCour 00-237-1369 pe of accred	Sep 2020 Sep 2020 n Baldridge nt) 9. <i>litation.</i>	mat	thew.miles@dia T:	7900 FM 608 ROSCOE, TX US 79545 ITHEW MILES

Contact/Location: MATTHEW MILES - MITROS