


PROBLEM SUMMARY


Area
SWEETWATER
Machine Id
D075
Component
Wind Turbine Gearbox
Fluid
MITSUBISHI Daphne Alpha Winforce (60 GAL)

Sample Rating Trend



COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	ABNORMAL
Particles >6µm	ASTM D7647	>5000	▲ 5734	▲ 8960	▲ 11428
Particles >14µm	ASTM D7647	>640	▲ 770	▲ 858	▲ 863
Particles >21µm	ASTM D7647	>160	▲ 217	▲ 234	▲ 246
Oil Cleanliness	ISO 4406 (c)	>--/19/16	▲ 21/20/17	▲ 22/20/17	▲ 23/21/17

Customer Id: MITROS
Sample No.: MHI018350
Lab Number: 05073862
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil.
Resample	---	---	?	Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil.

HISTORICAL DIAGNOSIS

27 May 2020 Diag: Don Baldrige

ISO



Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid.

[view report](#)



16 Mar 2020 Diag: Doug Bogart

ISO



Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid.

[view report](#)



26 Aug 2019 Diag: Doug Bogart

ISO




Re-sample to verify the actual oil condition. Replace filter elements. Change oil if cleanliness level does not improve after replacing the filter(s). All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid.

[view report](#)



OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
SWEETWATER
Machine Id
D075

Component
Wind Turbine Gearbox
Fluid
mitsubishi Daphne Alpha Winforce (60 GAL)

DIAGNOSIS

Recommendation

Replace filter element and resample at later date. In case already attempted and cleanliness was not improved then proceed to replace oil.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	MHI018350	MHI018402	MHI018411
Sample Date	Client Info	16 Sep 2020	27 May 2020	16 Mar 2020
Machine Age	hrs	0	0	0
Oil Age	hrs	103447	101085	99503
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

method	limit/base	current	history1	history2		
PQ	ASTM D8184	>200	16	20	20	
Iron	ppm	ASTM D5185m	>200	34	41	28
Chromium	ppm	ASTM D5185m		<1	<1	<1
Nickel	ppm	ASTM D5185m		2	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m		0	<1	0
Lead	ppm	ASTM D5185m		0	0	<1
Copper	ppm	ASTM D5185m	>75	13	12	10
Tin	ppm	ASTM D5185m		0	<1	<1
Antimony	ppm	ASTM D5185m		0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0

ADDITIVES

method	limit/base	current	history1	history2		
Boron	ppm	ASTM D5185m		1	<1	<1
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		2	2	2
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m		0	0	0
Calcium	ppm	ASTM D5185m		0	<1	0
Phosphorus	ppm	ASTM D5185m		319	353	314
Zinc	ppm	ASTM D5185m		23	0	7
Sulfur	ppm	ASTM D5185m		4261	4947	3742

CONTAMINANTS


method	limit/base	current	history1	history2		
Silicon	ppm	ASTM D5185m	>+30	2	4	<1
Sodium	ppm	ASTM D5185m		<1	<1	<1
Potassium	ppm	ASTM D5185m	>20	0	0	<1
Water	%	ASTM D6304	>0.1	0.005	0.008	0.013
ppm Water	ppm	ASTM D6304	>1000	52.1	84.8	132.7

FLUID CLEANLINESS


method	limit/base	current	history1	history2	
Particles >4µm	ASTM D7647		14876	35819	59936
Particles >6µm	ASTM D7647	>5000	▲ 5734	▲ 8960	▲ 11428
Particles >14µm	ASTM D7647	>640	▲ 770	▲ 858	▲ 863
Particles >21µm	ASTM D7647	>160	▲ 217	▲ 234	▲ 246
Particles >38µm	ASTM D7647	>40	13	12	12
Particles >71µm	ASTM D7647	>10	3	2	0
Oil Cleanliness	ISO 4406 (c)	>-/19/16	▲ 21/20/17	▲ 22/20/17	▲ 23/21/17

OIL ANALYSIS REPORT


Particle Trend




Water




PQ



Water



Viscosity @ 40°C




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		1.078	1.036	1.087

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG


FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445		323	321	325

SAMPLE IMAGES




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : MH1018350 **Received** : 25 Sep 2020
Lab Number : 05073862 **Diagnosed** : 28 Sep 2020
Unique Number : 9189093 **Diagnostician** : Don Baldrige
Test Package : IND 2 (Additional Tests: KF, PQ, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

DIAMOND W TG - SWEETWATER SITE - MPS SW
 7900 FM 608
 ROSCOE, TX
 US 79545

Contact: MATTHEW MILES
 matthew.miles@diamondwtg.com

T: (325)288-4333
 F: (325)288-4338