

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id 7024100 (S/N 1014) Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


		Jar	2020	May2020 Sep20	20				
SAMPLE INFORM	IATION	method	limit/base	current	history1	history2			
Sample Number		Client Info		KC85190	KC83610	KC84476			
Sample Date		Client Info		22 Sep 2020	22 May 2020	02 Jan 2020			
Machine Age	hrs	Client Info		8636	5897	2564			
Oil Age	hrs	Client Info		2800	3333	2564			
Oil Changed		Client Info		Not Changd	Changed	Changed			
Sample Status				NORMAL	NORMAL	NORMAL			
WEAR METALS		method	limit/base	current	history1	history2			
Iron	ppm	ASTM D5185m	>50	<1	<1	<1			
Chromium	ppm	ASTM D5185m	>10	0	0	0			
Nickel	ppm	ASTM D5185m	>3	<1	0	0			
Titanium	ppm	ASTM D5185m	>3	0	0	0			
Silver	ppm	ASTM D5185m	>2	0	0	0			
Aluminum	ppm	ASTM D5185m	>10	<1	1	0			
Lead	ppm	ASTM D5185m	>10	0	0	<1			
Copper	ppm	ASTM D5185m	>50	4	7	2			
Tin	ppm	ASTM D5185m	>10	<1	0	0			
Antimony	ppm	ASTM D5185m	-	0	0	0			
Vanadium	ppm	ASTM D5185m		0	0	<1			
Cadmium	ppm	ASTM D5185m		0	0	<1			
	ррпі								
ADDITIVES		method	limit/base	current	history1	history2			
Boron	ppm	ASTM D5185m		12	<1	<1			
Barium	ppm	ASTM D5185m	90	0	0	0			
Molybdenum	ppm	ASTM D5185m		0	0	0			
Manganese	ppm	ASTM D5185m		0	0	0			
Magnesium	ppm	ASTM D5185m	90	<1	0	1			
Calcium	ppm	ASTM D5185m	2	0	<1	0			
Phosphorus	ppm	ASTM D5185m		4	3	0			
Zinc	ppm	ASTM D5185m		41	0	5			
CONTAMINANTS		method	limit/base	current	history1	history2			
Silicon	ppm	ASTM D5185m	>25	2	<1	<1			
Sodium	ppm	ASTM D5185m		0	0	0			
Potassium	ppm	ASTM D5185m	>20	<1	0	0			
Water	%	ASTM D6304	>0.05	0.006	0.005	0.002			
ppm Water	ppm	ASTM D6304	>500	63.4	58.6	24.8			
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2			
Particles >4µm		ASTM D7647		1056	943	960			
Particles >6µm		ASTM D7647	>1300	243	230	421			
Particles >14µm		ASTM D7647	>80	11	6	28			
Particles >21µm		ASTM D7647	>20	3	0	8			
Particles >38µm		ASTM D7647	>4	0	0	0			
Particles >71µm		ASTM D7647	>3	0	0	0			
Oil Cleanliness		ISO 4406 (c)	>/17/13	15/11	15/10	16/12			
FLUID DEGRADA		method	limit/base	current	history1	history2			
Acid Number (AN)	mg KOH/g	ASTM D8045		0.447	0.407	0.462			
AGIG MUTTIDET (AIN)	ing NOTI/g	AUTINI DOU40	0.4	0.777	0.407	0.402			


Contact/Location: Service Manager - BETBIR




OIL ANALYSIS REPORT

	12000 -	Water	(KF)									
	10000.	Severe			 	 	 	 	 	 	 	 	1
(n	8000-					-							i.
Water (ppm)	6000-												
Wa	4000.												i.
	2000	Abnorma	1					 			 		
	0-	Jan 2/20				Mav22/20						00000 0	Sep 22/20





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	44.3	44.9	44.5
SAMPLE IMAGES	\$	method	limit/base	current	history1	history2
Color						
Bottom						



* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Contact/Location: Service Manager - BETBIR