

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



AG4030 (S/N 580356-002)

Component

Gearbox

WEAR GUARD ISO 68 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Aug2019	Jan 2021		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WCI2323454	WCI2323212	
Sample Date		Client Info		20 Jan 2021	14 Aug 2019	
Machine Age	hrs	Client Info		0	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				NORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	7	9	
Chromium	ppm	ASTM D5185m	>15	0	<1	
Nickel	ppm	ASTM D5185m	>15	0	<1	
Titanium	ppm	ASTM D5185m		0	0	
Silver	ppm	ASTM D5185m		0	0	
Aluminum	ppm	ASTM D5185m	>25	0	<1	
Lead	ppm	ASTM D5185m	>100	0	3	
Copper	ppm	ASTM D5185m	>200	0	<1	
Tin	ppm	ASTM D5185m	>25	0	2	
Antimony	ppm	ASTM D5185m		0	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	<1	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		2	<1	
Barium	ppm	ASTM D5185m		0	<1	
Molybdenum	ppm	ASTM D5185m		1	<1	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m		<1	1	
Calcium	ppm	ASTM D5185m		6	<1	
Phosphorus	ppm	ASTM D5185m		15	6	
Zinc	ppm	ASTM D5185m		0	<1	
Sulfur	ppm	ASTM D5185m		366	232	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	22	21	
Sodium	ppm	ASTM D5185m		0	2	
Potassium	ppm	ASTM D5185m	>20	<1	8	
Water	%	ASTM D6304	>0.2	NEG	NEG	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

Acid Number (AN)


mg KOH/g ASTM D8045

0.034


0.067



OIL ANALYSIS REPORT



GRAPHS Ferrous Alloys







Laboratory Sample No. Lab Number Unique Number

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : WCI2323454 : 05172589

: 9347872

Recieved : 02 Feb 2021 Diagnosed : 03 Feb 2021 Diagnostician : Jonathan Hester

ARKEMA INC 601 TIGHTSQUEEZE INDUSTRIAL RD CHATHAM, VA US 24531

Contact: CHRIS STALLARD marshall.stallard@arkema.com T: (434)432-3705

Test Package : IND 2 (Additional Tests: KF, PrtCount) Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F:

no image

no image