


PROBLEM SUMMARY

Sample Rating Trend



WATER





Machine Id
VILTER B

Component
Compressor

Fluid
VILTER METHANE PAO 100 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
Silicon	ppm	ASTM D5185m	>25	▲ 84	▲ 64	▲ 69
Water	%	ASTM D6304	>0.1	▲ 0.627	0.078	▲ 0.226
ppm Water	ppm	ASTM D6304	>1000	▲ 6270	780.4	▲ 2260
Silt	scalar	*Visual	NONE	▲ MODER	▲ MODER	NONE

Customer Id: MELMELTX
Sample No.: TO50000090
Lab Number: 05251613
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Jonathan Hester +1 919-379-4092 x4092
jhester@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Alert	---	---	?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

HISTORICAL DIAGNOSIS

28 Mar 2021 Diag: Jonathan Hester

DIRT



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. There is a moderate amount of visible silt present in the sample. Elemental level of silicon (Si) above normal indicating ingress of seal material. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



10 Feb 2021 Diag: Don Baldrige

WATER



We advise that you follow the water drain-off procedure for this component. We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a high amount of particulates present in the oil. There is a light concentration of water present in the oil. Elemental level of silicon (Si) above normal indicating ingress of seal material. The AN level is acceptable for this fluid.

[view report](#)



18 Aug 2020 Diag: Doug Bogart

WATER




The oil is near the end of its useful service life, recommend schedule an oil change. We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. An increase in the iron level is noted. All component wear rates are normal. There is a trace of moisture present in the oil. Moderate concentration of visible dirt/debris present in the oil. Elemental level of silicon (Si) above normal indicating ingress of seal material. The AN level is at the top-end of the recommended limit.

[view report](#)



OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Machine Id
VILTER B
 Component
Compressor
 Fluid
VILTER METHANE PAO 100 (--- GAL)

DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

There is a moderate concentration of water present in the oil. There is a moderate amount of visible silt present in the sample.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION	method	limit/base	current	history1	history2
Sample Number	Client Info		TO50000090	TO205215534	TO205180879
Sample Date	Client Info		06 May 2021	28 Mar 2021	10 Feb 2021
Machine Age	mths	Client Info	0	0	0
Oil Age	mths	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	29	27	▲ 116
Chromium	ppm	ASTM D5185m >10	0	0	0
Nickel	ppm	ASTM D5185m	1	0	0
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	<1	0	0
Aluminum	ppm	ASTM D5185m >25	<1	0	0
Lead	ppm	ASTM D5185m >25	0	0	0
Copper	ppm	ASTM D5185m >50	0	0	0
Tin	ppm	ASTM D5185m >15	0	<1	<1
Antimony	ppm	ASTM D5185m	2	<1	0
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0






ADDITIVES	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<1	<1	1
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0
Manganese	ppm	ASTM D5185m	<1	<1	1
Magnesium	ppm	ASTM D5185m	0	0	0
Calcium	ppm	ASTM D5185m	<1	0	0
Phosphorus	ppm	ASTM D5185m	5	<1	6
Zinc	ppm	ASTM D5185m	0	0	0
Sulfur	ppm	ASTM D5185m	2086	2173	2513

CONTAMINANTS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	▲ 84	▲ 64	▲ 69
Sodium	ppm	ASTM D5185m	2	0	<1
Potassium	ppm	ASTM D5185m >20	0	<1	<1
Water	%	ASTM D6304 >0.1	▲ 0.627	0.078	▲ 0.226
ppm Water	ppm	ASTM D6304 >1000	▲ 6270	780.4	▲ 2260

FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	---	---	▲ 46187
Particles >6µm	ASTM D7647	>2500	---	---	▲ 7634
Particles >14µm	ASTM D7647	>320	---	---	▲ 425
Particles >21µm	ASTM D7647	>80	---	---	▲ 132
Particles >38µm	ASTM D7647	>20	---	---	16
Particles >71µm	ASTM D7647	>4	---	---	3
Oil Cleanliness	ISO 4406 (c)	>20/18/15	---	---	▲ 23/20/16

FLUID DEGRADATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.857	0.132	0.959


OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	▲ MODER	▲ MODER
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	129	146	107
Visc @ 100°C	cSt	ASTM D445	19.0	17.5	16.0
Viscosity Index (VI)	Scale	ASTM D2270	166	131	160

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : TO50000090 **Received** : 11 May 2021
Lab Number : 05251613 **Diagnosed** : 13 May 2021
Unique Number : 9500523 **Diagnostician** : Jonathan Hester
Test Package : IND 2 (Additional Tests: KF, KV100, PrtCount, VI)

MELISSA RENEWABLES
 3820 SAM RAYBURN HWY
 MELISSA, TX
 US 75454
 Contact: BILL PALMER
 bpalmer@morrowenergy.com
 T: (972)529-8442
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)