

OIL ANALYSIS REPORT

Area **P2** 3543-A - 3540A CRYSTALLIZER Component

Gearbox

MOBIL MOBILGEAR 600 XP ISO 150 (44 QT

Sample Rating Trend



Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

TS)			Feb 2020	May/2021		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0565728	WC0425042	
Sample Date		Client Info		07 May 2021	24 Feb 2020	
Machine Age	hrs	Client Info		0	0	
Oil Age	hrs	Client Info		0	150	
Oil Changed		Client Info		N/A	Not Changd	
Sample Status				NORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	<1	<1	
Chromium	ppm	ASTM D5185m	>15	0	0	
Nickel	ppm	ASTM D5185m	>15	0	0	
Titanium	ppm	ASTM D5185m		0	0	
Silver	ppm	ASTM D5185m		2	2	
Aluminum	ppm	ASTM D5185m	>25	0	0	
Lead	ppm	ASTM D5185m	>100	<1	0	
Copper	ppm	ASTM D5185m	>200	<1	0	
Tin	ppm	ASTM D5185m	>25	0	0	
Antimony	ppm	ASTM D5185m		0	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	<1	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		22	29	
Barium	ppm	ASTM D5185m		0	<1	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		<1	0	
Magnesium	ppm	ASTM D5185m		<1	<1	
Calcium	ppm	ASTM D5185m		<1	0	
Phosphorus	ppm	ASTM D5185m		316	310	
Zinc	ppm	ASTM D5185m		0	0	
Sulfur	ppm	ASTM D5185m		13752	14118	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	0	0	
Sodium	ppm	ASTM D5185m		0	0	
Potassium	ppm	ASTM D5185m	>20	<1	<1	
Water	%	ASTM D6304	>0.2	0.012	0.008	
ppm Water	ppm	ASTM D6304	>2000	120.2	80	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>20000	1835	3846	
Particles >6µm		ASTM D7647	>5000	305	829	
Particles >14µm		ASTM D7647	>640	21	41	
Particles >21µm		ASTM D7647	>160	7	8	
Particles >38µm		ASTM D7647	>40	0	0	
Particles >71µm		ASTM D7647	>10	0	0	
Oil Cleanliness		ISO 4406 (c)	>21/19/16	18/15/12	19/17/13	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

Acid Number (AN)


mg KOH/g ASTM D8045

0.722

0.808



OIL ANALYSIS REPORT





Certificate L2367

Sample No. Lab Number **Unique Number**

: 05253319

: WC0565728 : 9502229

Diagnosed : 14 May 2021 Diagnostician : Don Baldridge

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) RALEIGH, NC US 27610

Contact: Michael Thompson thompsonm@ajiusa.com T: (919)723-2142