


COOLANT REPORT



KANSAS/44/EG - EXCAVATOR 20.12W [KANSAS^44^EG - EXCAVATOR] Component

Coolant

CAT EXTENDED LIFE COOLANT (ELC) (--- GAL)





Recommendation

No corrective action is recommended at this time. The fluid is suitable for further service.

Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

Contaminants

There is no indication of any contamination in the coolant.


Coolant Condition

Carboxylate test failed. Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.


		56	12019	oobsoso oobso	261	
SAMPLE INFORM	NOITAN	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0621058	WC0495423	WC0386474
Sample Date		Client Info		27 Sep 2021	29 Sep 2020	10 Sep 2019
Machine Age		Client Info		5947	0	5073
Oil Age		Client Info		5866	0	2000
Oil Changed		Client Info		Not Changd	Not Changd	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL
PHYSICAL TEST R	ESULTS	method	limit/base	current	history1	history2
рН	Scale 0-14	ASTM D1287		8.10	8.14	8.24
Nitrites	ppm	AP-053:2009		560	676	788
Reserve Alkalinity	Scale 0-20	*ASTM D1121				
Percentage Glycol	%	ASTM D3321		50	50	50
Freezing Point	°F	ASTM D3321		-39	-39	-38
Total Dissolved Solids				397.5	379.0	380.0
Carboxylate				fail	pass	pass
CORROSION INHI	IBITORS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D6130	0	12	11	5
Phosphorus	ppm	ASTM D6130	0	0	<1	<1
Boron	ppm	ASTM D6130	0	0	<1	0
Molybdenum	ppm	ASTM D6130	950	713	1073	595
CORROSION		method	limit/base	current	history1	history2
Iron	ppm	ASTM D6130	>15	<1	<1	0
Aluminum	ppm	ASTM D6130	>10	<1	9	4
Copper	ppm	ASTM D6130	>10	<1	<1	0
Lead	ppm	ASTM D6130	>10	0	<1	0
Tin	ppm	ASTM D6130	>10	0	2	<1
Zinc	ppm	ASTM D6130		0	<1	0
CONTAMINANTS		method	limit/base	current	history1	history2
Chlorine	ppm	ASTM D6130		3	8	2
CARRIER SALTS		method	limit/base	current	history1	history2
Sodium	ppm	ASTM D6130		3450	3683	3143
Potassium	ppm	ASTM D6130		1982	375	312
SCALE POTENTIA	AL	method	limit/base	current	history1	history2
Calcium	ppm	ASTM D6130		2	3	1
Magnesium	ppm	ASTM D6130		4	2	<1
J	1-1					



COOLANT REPORT









Laboratory Sample No. Lab Number Unique Number : 9682430

: WC0621058 : 05363324

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 30 Sep 2021 Diagnosed

: 06 Oct 2021 Diagnostician : Doug Bogart

Test Package : COOL- (Additional Tests: COOL, ICP) To discuss this sample report, contact Customer Service at 1-800-237-1369.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

SHERWOOD CONSTRUCTION CO INC

3219 WEST MAY ST WICHITA, KS US 67213 Contact: DOUG KING doug.king@sherwood.net

T: (316)617-3161

F: x: