


OIL ANALYSIS REPORT

Sample Rating Trend







CTG-300 Component

Reservoir Oil

MOBIL DTE 824 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Feb 2019	Sep2019 Jun2020	D Feb 2021 Mar 2021	0ct2021	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		RP0022450	RP0016539	RP0013459
Sample Date		Client Info		06 Oct 2021	02 Mar 2021	10 Feb 2021
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	<1	<1	<1
Chromium	ppm	ASTM D5185m	>20	0	0	0
Nickel	ppm	ASTM D5185m	>20	<1	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		<1	0	0
Aluminum	ppm	ASTM D5185m	>20	0	0	0
Lead	ppm	ASTM D5185m	>20	<1	0	<1
Copper	ppm	ASTM D5185m	>20	<1	<1	<1
Tin	ppm	ASTM D5185m	>20	<1	<1	0
Antimony	ppm	ASTM D5185m		0	0	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	<1	<1
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m		<1	0	0
Calcium	ppm	ASTM D5185m		0	<1	<1
Phosphorus	ppm	ASTM D5185m		1066	1173	1102
Zinc	ppm	ASTM D5185m		0	0	0
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	0	<1	0
Sodium	ppm	ASTM D5185m		8	11	13
Potassium	ppm	ASTM D5185m	>20	<1	0	0
						0.000
Water	%	ASTM D6304		0.006	0.003	0.003
Water ppm Water	% ppm	ASTM D6304 ASTM D6304		0.006 66.6	0.003 32.8	36.1

Acid Number (AN) mg KOH/g ASTM D8045

0.187

0.202

0.179



OIL ANALYSIS REPORT







Laboratory Sample No. Lab Number **Unique Number**

: 05368612

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : RP0022450

: 9687718

Recieved : 07 Oct 2021 : 11 Oct 2021 Diagnosed Diagnostician

: Doug Bogart

Test Package : IND 2 (Additional Tests: PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

ENGIE-MATEP 474 BROOKLINE AVE

BOSTON, MA US 02215

Contact: ROBERT ST SAUVEUR robert.stsauveur@engie.com

T: (401)651-9381

F: