


# **OIL ANALYSIS REPORT**

Sample Rating Trend



**NORMAL** 



# Machine Id **7471622 (S/N 1038)**

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

## Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

## **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			May2021	Nov2021		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC95721	KC90141	
Sample Date		Client Info		17 Nov 2021	20 May 2021	
Machine Age	hrs	Client Info		501	368	
Oil Age	hrs	Client Info		501	368	
Oil Changed	1110	Client Info		Changed	Not Changd	
Sample Status				NORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	1	<1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	<1	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	<1	0	
Lead	ppm	ASTM D5185m	>10	0	<1	
Copper	ppm	ASTM D5185m	>50	<1	<1	
Tin	ppm	ASTM D5185m	>10	0	0	
Antimony	ppm	ASTM D5185m		3	0	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	19	<1	
Barium	ppm	ASTM D5185m	90	18	57	
Molybdenum	ppm	ASTM D5185m	0	2	0	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m	100	88	79	
Calcium	ppm	ASTM D5185m	0	2	2	
Phosphorus	ppm	ASTM D5185m	0	5	0	
Zinc	ppm	ASTM D5185m	0	5	0	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	
Sodium	ppm	ASTM D5185m		10	7	
Potassium	ppm	ASTM D5185m	>20	8	3	
Water	%	ASTM D6304	>0.05	0.019	0.025	
ppm Water	ppm	ASTM D6304	>500	199.8	259.5	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		4218	2611	
Particles >6µm		ASTM D7647	>1300	992	607	
Particles >14µm		ASTM D7647	>80	42	36	
Particles >21µm		ASTM D7647	>20	11	10	
Particles >38µm		ASTM D7647	>4	0	0	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/13	16/12	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
A siel Niversia en (ANI)	I/OII/-	ACTM DOG45	1.0	0.201	0.055	

Acid Number (AN)

mg KOH/g ASTM D8045 1.0

0.355

0.381



## **OIL ANALYSIS REPORT**







Certificate L2367

Sample No. Lab Number Unique Number Test Package

: KC95721 : 05408736 : 9752899 : IND 2

Recieved Diagnosed

: 26 Nov 2021 Diagnostician

: Angela Borella

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

STRONGSVILLE, OH US 44149

Contact: Service Manager

T: F: