


OIL ANALYSIS REPORT



ISO

7463760 (S/N 1030)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

| | | | May2021 | Nov2021 | | |
|-----------------|--------|--------------|------------|--------------|-------------|----------|
| SAMPLE INFORM | MATION | method | limit/base | current | history1 | history2 |
| Sample Number | | Client Info | | KC95713 | KC90142 | |
| Sample Date | | Client Info | | 17 Nov 2021 | 20 May 2021 | |
| Machine Age | hrs | Client Info | | 1812 | 368 | |
| Oil Age | hrs | Client Info | | 1812 | 368 | |
| Oil Changed | | Client Info | | Changed | Not Changd | |
| Sample Status | | | | ABNORMAL | ATTENTION | |
| WEAR METALS | | method | limit/base | current | history1 | history2 |
| Iron | ppm | ASTM D5185m | >50 | 2 | <1 | |
| Chromium | ppm | ASTM D5185m | >10 | 0 | 0 | |
| Nickel | ppm | ASTM D5185m | >3 | <1 | 0 | |
| Titanium | ppm | ASTM D5185m | >3 | 0 | 0 | |
| Silver | ppm | ASTM D5185m | >2 | 0 | 0 | |
| Aluminum | ppm | ASTM D5185m | >10 | <1 | 0 | |
| Lead | ppm | ASTM D5185m | >10 | <1 | <1 | |
| Copper | ppm | ASTM D5185m | >50 | 4 | <1 | |
| Tin | ppm | ASTM D5185m | >10 | 0 | 0 | |
| Antimony | ppm | ASTM D5185m | | 2 | 0 | |
| Vanadium | ppm | ASTM D5185m | | <1 | 0 | |
| Cadmium | ppm | ASTM D5185m | | 0 | 0 | |
| ADDITIVES | | method | limit/base | current | history1 | history2 |
| Boron | ppm | ASTM D5185m | | 17 | <1 | |
| Barium | ppm | ASTM D5185m | 90 | <1 | 59 | |
| Molybdenum | ppm | ASTM D5185m | | 0 | 0 | |
| Manganese | ppm | ASTM D5185m | | <1 | <1 | |
| Magnesium | ppm | ASTM D5185m | 90 | 36 | 77 | |
| Calcium | ppm | ASTM D5185m | 2 | <1 | 2 | |
| Phosphorus | ppm | ASTM D5185m | | 4 | 0 | |
| Zinc | ppm | ASTM D5185m | | 14 | 0 | |
| CONTAMINANTS | ; | method | limit/base | current | history1 | history2 |
| Silicon | ppm | ASTM D5185m | >25 | 1 | 0 | |
| Sodium | ppm | ASTM D5185m | | 12 | 6 | |
| Potassium | ppm | ASTM D5185m | >20 | 11 | 3 | |
| Water | % | ASTM D6304 | >0.05 | 0.016 | 0.024 | |
| ppm Water | ppm | ASTM D6304 | >500 | 163.2 | 245.7 | |
| FLUID CLEANLIN | IESS | method | limit/base | current | history1 | history2 |
| Particles >4µm | | ASTM D7647 | | 4978 | 8207 | |
| Particles >6µm | | ASTM D7647 | >1300 | 1794 | ▲ 2383 | |
| Particles >14µm | | ASTM D7647 | >80 | 415 | 1 39 | |
| Particles >21µm | | ASTM D7647 | >20 | <u> </u> | A 37 | |
| Particles >38µm | | ASTM D7647 | >4 | <u>^</u> 6 | 3 | |
| Particles >71μm | | ASTM D7647 | >3 | 0 | 0 | |
| Oil Cleanliness | | ISO 4406 (c) | >/17/13 | 18/16 | ▲ 18/14 | |
| FLUID DEGRADA | ATION | method | limit/base | current | history1 | history2 |
| | | | | 0.225 | 0.240 | |

Acid Number (AN)


mg KOH/g ASTM D8045 0.4

0.349

0.335



OIL ANALYSIS REPORT







Certificate L2367

Sample No. Lab Number **Unique Number**

: KC95713 : 05408749 : 9752912

Test Package : IND 2

: 24 Nov 2021 Recieved Diagnosed : 02 Dec 2021

: Jonathan Hester Diagnostician

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

US 44149

T: F:

STRONGSVILLE, OH

Contact: Service Manager