

PROBLEM SUMMARY


Area
[PLANT 2371]
 Machine Id
ALPHA BLUE HEATER (S/N 97093)
 Component
Heat Transfer Fluid
 Fluid
TULCO LUBSOIL HEAT TRANSFER 250 (--- GAL)

Sample Rating Trend




COMPONENT CONDITION SUMMARY

Acid Number



Ferrous Alloys



RECOMMENDATION

Recommend drain oil if not already done and flush with cleaner before refilling with oil. Please note that the oil was too thick to perform some of the normal laboratory tests.

PROBLEMATIC TEST RESULTS

| Sample Status | | | | SEVERE | ABNORMAL | --- |
|------------------|----------|-------------|------|--------|----------|-----|
| Iron | ppm | ASTM D5185m | | 742 | 439 | --- |
| Acid Number (AN) | mg KOH/g | ASTM D8045 | 0.05 | 5.431 | 0.891 | --- |
| Debris | scalar | *Visual | NONE | SOLID | NONE | --- |

Customer Id: BLUMUSOK
 Sample No.: TO10000612
 Lab Number: 05413687
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

| Action | Status | Date | Done By | Description |
|--------------|--------|-------------|---------|---|
| Change Fluid | MISSED | Oct 03 2022 | ? | Recommend drain oil if not already done and flush with cleaner before refilling with oil. |
| Flush System | MISSED | Oct 03 2022 | ? | Recommend drain oil if not already done and flush with cleaner before refilling with oil. |
| Alert | --- | --- | ? | Please note that the fluid was too thick to perform some of the normal laboratory tests. |

HISTORICAL DIAGNOSIS

06 Feb 2020 Diag: Doug Bogart

WEAR




Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please note that this is a corrected copy for data entry updates. The iron level is abnormal. There is no indication of any contamination in the oil. The oil viscosity is higher than normal. The AN level is acceptable for this fluid.

view report



OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Area
[PLANT 2371]
 Machine Id
ALPHA BLUE HEATER (S/N 97093)
 Component
Heat Transfer Fluid
 Fluid
TULCO LUBSOIL HEAT TRANSFER 250 (--- GAL)

DIAGNOSIS

- Recommendation**
 Recommend drain oil if not already done and flush with cleaner before refilling with oil. Please note that the oil was too thick to perform some of the normal laboratory tests.
- Wear**
 The iron level is abnormal.
- Contamination**
 No contaminants were detected in the oil.
- Fluid Condition**
 The AN level is above the recommended limit. The oil is highly oxidized and beyond the limit of serviceability.

SAMPLE INFORMATION

| | method | limit/base | current | history1 | history2 |
|---------------|-------------|-------------|--------------------|-------------|----------|
| Sample Number | Client Info | | TO10000612 | TO1002080 | --- |
| Sample Date | Client Info | | 23 Nov 2021 | 06 Feb 2020 | --- |
| Machine Age | mths | Client Info | 0 | 0 | --- |
| Oil Age | mths | Client Info | 0 | 0 | --- |
| Oil Changed | Client Info | | N/A | N/A | --- |
| Sample Status | | | SEVERE | ABNORMAL | --- |

WEAR METALS

| | method | limit/base | current | history1 | history2 |
|----------|--------|-------------|--------------|----------|----------|
| Iron | ppm | ASTM D5185m | 742 | 439 | --- |
| Chromium | ppm | ASTM D5185m | <1 | <1 | --- |
| Nickel | ppm | ASTM D5185m | 0 | <1 | --- |
| Titanium | ppm | ASTM D5185m | <1 | <1 | --- |
| Silver | ppm | ASTM D5185m | 0 | 0 | --- |
| Aluminum | ppm | ASTM D5185m | <1 | <1 | --- |
| Lead | ppm | ASTM D5185m | 0 | <1 | --- |
| Copper | ppm | ASTM D5185m | <1 | <1 | --- |
| Tin | ppm | ASTM D5185m | 0 | 0 | --- |
| Antimony | ppm | ASTM D5185m | 0 | 0 | --- |
| Vanadium | ppm | ASTM D5185m | 0 | 0 | --- |
| Cadmium | ppm | ASTM D5185m | 0 | 0 | --- |

ADDITIVES

| | method | limit/base | current | history1 | history2 |
|------------|--------|------------------|--------------|----------|----------|
| Boron | ppm | ASTM D5185m | 31 | <1 | --- |
| Barium | ppm | ASTM D5185m | 0 | 0 | --- |
| Molybdenum | ppm | ASTM D5185m | <1 | 0 | --- |
| Manganese | ppm | ASTM D5185m | 8 | 5 | --- |
| Magnesium | ppm | ASTM D5185m | 1 | 1 | --- |
| Calcium | ppm | ASTM D5185m | 16 | 24 | --- |
| Phosphorus | ppm | ASTM D5185m | 13 | 14 | --- |
| Zinc | ppm | ASTM D5185m | 10 | 70 | --- |
| Sulfur | ppm | ASTM D5185m 1400 | 913 | 1285 | --- |
| Lithium | ppm | ASTM D5185m | 0 | --- | --- |



CONTAMINANTS

| | method | limit/base | current | history1 | history2 |
|-----------|--------|-----------------|--------------|----------|----------|
| Silicon | ppm | ASTM D5185m | <1 | 0 | --- |
| Sodium | ppm | ASTM D5185m | 7 | 8 | --- |
| Potassium | ppm | ASTM D5185m >20 | 0 | <1 | --- |
| Water | % | ASTM D6304 | NEG | NEG | --- |

FLUID DEGRADATION

| | method | limit/base | current | history1 | history2 |
|------------------|----------|-----------------|--------------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 0.05 | 5.431 | 0.891 | --- |

OIL ANALYSIS REPORT






| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | --- |
| Yellow Metal | scalar | *Visual | NONE | NONE | --- |
| Precipitate | scalar | *Visual | NONE | NONE | --- |
| Silt | scalar | *Visual | NONE | NONE | --- |
| Debris | scalar | *Visual | NONE | ▲ SOLID | --- |
| Sand/Dirt | scalar | *Visual | NONE | NONE | --- |
| Appearance | scalar | *Visual | NORML | NORML | --- |
| Odor | scalar | *Visual | NORML | NORML | --- |
| Emulsified Water | scalar | *Visual | NEG | NEG | --- |
| Free Water | scalar | *Visual | NEG | NEG | --- |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|----------------------|--------|------------|---------|----------|----------|
| Visc @ 40°C | cSt | ASTM D445 | 52 | --- | ▲ 145 |
| Visc @ 100°C | cSt | ASTM D445 | 7.5 | --- | ▲ 17.5 |
| Viscosity Index (VI) | Scale | ASTM D2270 | 106 | --- | 132 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
| Color | | | | | no image |
| Bottom | | | | | no image |

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : TO10000612 **Received** : 02 Dec 2021
Lab Number : 05413687 **Diagnosed** : 07 Dec 2021
Unique Number : 9762875 **Diagnostician** : Doug Bogart
Test Package : IND 2 (Additional Tests: KF, KV100, PrtCount, VI)

ERGON - CALLERY - ALPHA - BETA - DELTA
 2501 PORT PL
 MUSKOGEE, OK
 US 74403
 Contact: COLE HOWELL
 Donovan.Howell@ergon.com
 T:
 F: (918)683-6061

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)