




# PROBLEM SUMMARY

## Sample Rating Trend

ISO




Area  
**UTL**  
 Machine Id  
**A65P001 BOILER FEED PUMP A**  
 Component  
**Hydraulic System**  
 Fluid  
**PETRO CANADA HYDREX AW 46 (30 GAL)**



## COMPONENT CONDITION SUMMARY

### ▲ Particle Trend



## RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL
Particles >4µm	ASTM D7647	>5000	▲ <b>43456</b>	▲ 33990	---
Particles >6µm	ASTM D7647	>1300	▲ <b>4725</b>	▲ 5373	---
Oil Cleanliness	ISO 4406 (c)	>19/17/14	▲ <b>23/19/13</b>	▲ 22/20/15	---

Customer Id: INGBED  
 Sample No.: WC0647343  
 Lab Number: 05422955  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Doug Bogart +1 (800)237-1369 x4016  
[dougb@wearcheckusa.com](mailto:dougb@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component if applicable.

## HISTORICAL DIAGNOSIS

### 10 Nov 2021 Diag: Don Baldrige

#### VISCOSITY



We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. Viscosity of sample indicates oil is within ISO 46 range, advise investigate. Confirm oil type. The AN level is acceptable for this fluid.

[view report](#)



### 13 Oct 2021 Diag: Doug Bogart

#### VISCOSITY



We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. Viscosity of sample indicates oil is within ISO 46 range, advise investigate. Confirm oil type. The AN level is acceptable for this fluid.

[view report](#)



### 30 Sep 2021 Diag: Don Baldrige

#### VISCOSITY



We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. Viscosity of sample indicates oil is within ISO 46 range, advise investigate. Confirm oil type. The AN level is acceptable for this fluid.


[view report](#)





# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area  
**UTL**  
 Machine Id  
**A65P001 BOILER FEED PUMP A**  
 Component  
**Hydraulic System**  
 Fluid  
**PETRO CANADA HYDREX AW 46 (30 GAL)**

## DIAGNOSIS

### Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0647343</b>	WC0621306	WC05374293
Sample Date	Client Info		<b>08 Dec 2021</b>	10 Nov 2021	13 Oct 2021
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >20	<b>0</b>	<1	0
Chromium	ppm	ASTM D5185m >20	<b>0</b>	<1	0
Nickel	ppm	ASTM D5185m >20	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Aluminum	ppm	ASTM D5185m >20	<b>0</b>	0	<1
Lead	ppm	ASTM D5185m >20	<b>5</b>	6	5
Copper	ppm	ASTM D5185m >20	<b>34</b>	36	35
Tin	ppm	ASTM D5185m >20	<b>&lt;1</b>	<1	<1
Antimony	ppm	ASTM D5185m	<b>0</b>	0	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	<1

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	<b>0</b>	<1	0
Barium	ppm	ASTM D5185m 0	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m 0	<b>&lt;1</b>	<1	0
Manganese	ppm	ASTM D5185m 0	<b>0</b>	0	<1
Magnesium	ppm	ASTM D5185m 0	<b>6</b>	7	7
Calcium	ppm	ASTM D5185m 50	<b>16</b>	18	16
Phosphorus	ppm	ASTM D5185m 330	<b>156</b>	118	113
Zinc	ppm	ASTM D5185m 430	<b>109</b>	131	124
Sulfur	ppm	ASTM D5185m 760	<b>2379</b>	2483	2415

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	<b>&lt;1</b>	<1	0
Sodium	ppm	ASTM D5185m	<b>&lt;1</b>	0	<1
Potassium	ppm	ASTM D5185m >20	<b>0</b>	<1	0

## FLUID CLEANLINESS





	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	<b>▲ 43456</b>	▲ 33990	---
Particles >6µm	ASTM D7647	>1300	<b>▲ 4725</b>	▲ 5373	---
Particles >14µm	ASTM D7647	>160	<b>45</b>	▲ 253	---
Particles >21µm	ASTM D7647	>40	<b>8</b>	▲ 41	---
Particles >38µm	ASTM D7647	>10	<b>0</b>	2	---
Particles >71µm	ASTM D7647	>3	<b>0</b>	0	---
Oil Cleanliness	ISO 4406 (c)	>19/17/14	<b>▲ 23/19/13</b>	▲ 22/20/15	---

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.70	<b>0.079</b>	0.095	0.12




# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46.4	44.1 ▲	43.9 ▲

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0647343 **Received** : 15 Dec 2021  
**Lab Number** : 05422955 **Diagnosed** : 15 Dec 2021  
**Unique Number** : 9777146 **Diagnostician** : Doug Bogart  
**Test Package** : IND 2

**INGREDION - BEDFORD PARK**  
 6400 SOUTH ARCHER ROAD  
 BEDFORD PARK, IL  
 US 60501  
 Contact: Ricardo Gutierrez  
 Ricardo.Gutierrez@ingredion.com  
 T: (219)805-1307  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)