


# **OIL ANALYSIS REPORT**

Area [142791] **KAESER 7423557** 

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)





# Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Aug2021	Dec2021		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC96403	KC82700	
Sample Date		Client Info		28 Dec 2021	30 Aug 2021	
Machine Age	hrs	Client Info		4703	3202	
Oil Age	hrs	Client Info		2453	952	
Oil Changed		Client Info		Changed	Not Changd	
Sample Status				NORMAL	ATTENTION	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	<1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	<1	0	
Aluminum	ppm	ASTM D5185m	>10	<1	<1	
Lead	ppm	ASTM D5185m	>10	0	<1	
Copper	ppm	ASTM D5185m	>50	<1	<1	
Tin	ppm	ASTM D5185m	>10	<1	0	
Antimony	ppm	ASTM D5185m		0	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		22	19	
Barium	ppm	ASTM D5185m	90	12	38	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m	90	80	87	
Calcium	ppm	ASTM D5185m	2	2	1	
Phosphorus	ppm	ASTM D5185m		1	0	
Zinc	ppm	ASTM D5185m		0	<1	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	4	
Sodium	ppm	ASTM D5185m		9	7	
Potassium	ppm	ASTM D5185m	>20	5	8	
Water	%	ASTM D6304	>0.05	0.018	0.025	
ppm Water	ppm	ASTM D6304	>500	184.9	259.0	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		1435	4136	
Particles >6μm		ASTM D7647	>1300	509	<u>1454</u>	
Particles >14μm		ASTM D7647	>80	58	<u> </u>	
Particles >21µm		ASTM D7647	>20	17	17	
Particles >38μm		ASTM D7647	>4	2	1	
Particles >71μm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	16/13	<b>▲</b> 18/14	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.317	0.316	



## **OIL ANALYSIS REPORT**







Certificate L2367

Sample No. Lab Number **Unique Number** Test Package

: 9812388

Received : 13 Jan 2022 0.05443194Diagnosed : 14 Jan 2022 Diagnostician

: Don Baldridge

500 32ND ST SW BONDURANT, IA US 50035 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

: IND 2

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: