

OIL ANALYSIS REPORT

Sample Rating Trend



T145197 (S/N 1205)

Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


			Jan2021	Jan2022		
SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC95268	KC91935	
Sample Date		Client Info		27 Jan 2022	06 Jan 2021	
Machine Age	hrs	Client Info		4805	2074	
Oil Age	hrs	Client Info		2762	2074	
Oil Changed		Client Info		Changed	Changed	
Sample Status				NORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	1	2	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	<1	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	<1	0	
Aluminum	ppm	ASTM D5185m	>10	<1	<1	
Lead	ppm	ASTM D5185m	>10	<1	0	
Copper	ppm	ASTM D5185m	>50	19	10	
Tin	ppm	ASTM D5185m	>10	0	0	
Antimony	ppm	ASTM D5185m		<1	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		21	10	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m	90	33	53	
Calcium	ppm	ASTM D5185m	2	<1	<1	
Phosphorus	ppm	ASTM D5185m		3	2	
Zinc	ppm	ASTM D5185m		13	6	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2	<1	
Sodium	ppm	ASTM D5185m		15	15	
Potassium	ppm	ASTM D5185m	>20	5	5	
Water	%	ASTM D6304	>0.05	0.002	0.014	
opm Water	ppm	ASTM D6304	>500	20.3	147.8	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		2637		
Particles >6µm		ASTM D7647	>1300	939		
Particles >14µm		ASTM D7647	>80	40		
Particles >21µm		ASTM D7647	>20	4		
Particles >38µm		ASTM D7647	>4	0		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/12		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.37	0.342	




OIL ANALYSIS REPORT









Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Lab Number

Unique Number

Contact/Location: Service Manager - NOVBED

T:

F: