

# **PROBLEM SUMMARY**

Sample Rating Trend

ISO


# KAESER 7151738

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

## **COMPONENT CONDITION SUMMARY**



#### RECOMMENDATION

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ATTENTION	ATTENTION					
Particles >6µm	ASTM D7647	>1300	<b>4</b> 2482	871					
Particles >14µm	ASTM D7647	>80	<u> </u>	<u> </u>					
Particles >21µm	ASTM D7647	>20	<u>^</u> 21	<b>4</b> 0					
Oil Cleanliness	ISO 4406 (c)	>/17/13	<b>18/14</b>	<u></u> 17/14					

Customer Id: MCKLEB Sample No.: KC89545 Lab Number: 05462576 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED	ACTIONS			
Action	Status	Date	Done By	Description
Change Fluid			?	Oil and filter change at the time of sampling has been noted.
Change Filter			?	Oil and filter change at the time of sampling has been noted.

## HISTORICAL DIAGNOSIS

09 Jun 2021 Diag: Angela Borella






The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





# **OIL ANALYSIS REPORT**



ISO



**KAESER 7151738** 

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

## **DIAGNOSIS**

#### Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is a moderate amount of particulates present in the oil.


#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Jun2021	Jan 2022		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC89545	KC91176	
Sample Date		Client Info		25 Jan 2022	09 Jun 2021	
Machine Age	hrs	Client Info		8728	6093	
Oil Age	hrs	Client Info		5975	3340	
Oil Changed		Client Info		Changed	Not Changd	
Sample Status				ATTENTION	ATTENTION	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	1	<1	
Lead	ppm	ASTM D5185m	>10	0	2	
Copper	ppm	ASTM D5185m	>50	12	4	
Tin	ppm	ASTM D5185m	>10	0	<1	
Antimony	ppm	ASTM D5185m		0	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<1	14	
Barium	ppm	ASTM D5185m	90	0	24	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m	90	0	36	
Calcium	ppm	ASTM D5185m	2	0	0	
Phosphorus	ppm	ASTM D5185m		4	2	
Zinc	ppm	ASTM D5185m		0	<1	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	0	
Sodium	ppm	ASTM D5185m	725	1	9	
Potassium	ppm	ASTM D5185m	>20	0	2	
Water	%	ASTM D5103111	>0.05	0.004	0.019	
ppm Water	ppm	ASTM D6304	>500	47.1	191.0	
FLUID CLEANLIN		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		8724	2462	
Particles >6µm		ASTM D7647	>1300	<u>^</u> 2482	871	
Particles >14µm		ASTM D7647	>80	<u> </u>	▲ 118	
Particles >21µm		ASTM D7647		<u> </u>	<u></u> 40	
Particles >38µm		ASTM D7647	>4	0	1	
Particles >71µm		ASTM D7647		0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u> </u>	▲ 17/14	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.46	0.373	



## **OIL ANALYSIS REPORT**





Certificate L2367

Sample No. Lab Number **Unique Number** 

: KC89545 : 05462576

: 9841772 : IND 2

: 08 Feb 2022 Received Diagnosed : 09 Feb 2022 Diagnostician : Don Baldridge

Test Package To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

LEBANON, IN

Contact: Service Manager

US 46052

T: F: