


# PROBLEM SUMMARY

Sample Rating Trend



**WEAR**




Machine Id  
**DIRECT CAST TILT HYD DCTHYD**

Component  
**Main Hydraulic System**

Fluid  
**FIRE-RESISTANT FLUID ISO 46 (150 GAL)**

## COMPONENT CONDITION SUMMARY



## RECOMMENDATION

We recommend that you drain the oil and perform a filter service on this component if not already done. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample. Due to an abnormal test result it is recommended to contact Stauff Corp at (201)-444-7800 for help resolving the issue.

## PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	ABNORMAL	NORMAL
Iron	ppm	ASTM D5185m	>20	57	12	0
Copper	ppm	ASTM D5185m	>20	113	15	<1
Zinc	ppm	ASTM D5185m	62	492	56	2
Sulfur	ppm	ASTM D5185m	500	1194	118	14
Water	%	ASTM D6304	>55	0.785	44.6	41.0
ppm Water	ppm	ASTM D6304	>55000	7850	446000	410000
Debris	scalar	*Visual	NONE	MODER	LIGHT	NONE
Appearance	scalar	*Visual	NORML	LAYRD	LAYRD	NORML
Free Water	scalar	*Visual		10.0	NEG	NEG

Customer Id: KOBPIN  
Sample No.: ST37295  
Lab Number: 05470209  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Jonathan Hester +1 919-379-4092 x4092  
[jhester@wearcheckusa.com](mailto:jhester@wearcheckusa.com)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	MISSED	Feb 20 2023	?	We recommend that you drain the oil and perform a filter service on this component if not already done.
Change Filter	MISSED	Feb 20 2023	?	We recommend that you drain the oil and perform a filter service on this component if not already done.
Resample	MISSED	Feb 20 2023	?	We recommend an early resample to monitor this condition.
Contact Required	MISSED	Feb 20 2023	?	Due to an abnormal test result it is recommended to contact Stauff Corp at (201)-444-7800 for help resolving the issue.
Alert	---	---	?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

## HISTORICAL DIAGNOSIS

### 15 Feb 2021 Diag: Doug Bogart

#### WEAR



We recommend you service the filters on this component. Resample at the next service interval to monitor. Due to an abnormal test result it is recommended to contact Stauff Corp at (201)-444-7800 for help resolving the issue. An increase in the iron and cooped levels noted. All other component wear rates are normal. There is a high amount of particulates present in the oil. The pH level of this fluid is within the acceptable limits at 7.0. The condition of the oil is acceptable for the time in service.

[view report](#)



### 04 Mar 2019 Diag: Doug Bogart

#### NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The pH level of this fluid is within the acceptable limits. The condition of the oil is suitable for further service.

[view report](#)



### 26 Sep 2018 Diag: Jonathan Hester


#### NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)





Machine Id  
**DIRECT CAST TILT HYD DCTHYD**  
 Component  
**Main Hydraulic System**  
 Fluid  
**FIRE-RESISTANT FLUID ISO 46 (150 GAL)**

## DIAGNOSIS

**Recommendation**  
 We recommend that you drain the oil and perform a filter service on this component if not already done. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample. Due to an abnormal test result it is recommended to contact Stauff Corp at (201)-444-7800 for help resolving the issue.

**Wear**  
 The iron level is severe. The copper level is abnormal.

**Contamination**  
 Excessive free water present. Moderate concentration of visible dirt/debris present in the oil. The water value is lower than typical, possibly indicating the addition of different type of oil.

**Fluid Condition**  
 Additive levels indicate the addition of a different brand, or type of oil.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>ST37295</b>	ST42600	ST40120
Sample Date	Client Info	<b>10 Feb 2022</b>	15 Feb 2021	04 Mar 2019
Machine Age	hrs	<b>0</b>	0	0
Oil Age	hrs	<b>0</b>	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>SEVERE</b>	ABNORMAL	NORMAL

## WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >20	<b>57</b>	12	0
Chromium	ppm	ASTM D5185m >20	<b>4</b>	<1	0
Nickel	ppm	ASTM D5185m >20	<1	<1	0
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m	<1	<1	0
Aluminum	ppm	ASTM D5185m >20	<b>0</b>	<1	0
Lead	ppm	ASTM D5185m >20	<1	<1	0
Copper	ppm	ASTM D5185m >20	<b>113</b>	15	<1
Tin	ppm	ASTM D5185m >20	<1	<1	0
Antimony	ppm	ASTM D5185m	<b>0</b>	0	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<1	<1	0

## ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m 5	<b>3</b>	2	<1
Barium	ppm	ASTM D5185m 5	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m 5	<1	<1	0
Manganese	ppm	ASTM D5185m	<b>1</b>	<1	0
Magnesium	ppm	ASTM D5185m 5	<b>2</b>	1	0
Calcium	ppm	ASTM D5185m 50	<b>18</b>	4	0
Phosphorus	ppm	ASTM D5185m 175	<b>119</b>	12	<1
Zinc	ppm	ASTM D5185m 62	<b>492</b>	56	2
Sulfur	ppm	ASTM D5185m 500	<b>1194</b>	118	14

## CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >15	<b>21</b>	11	<1
Sodium	ppm	ASTM D5185m	<b>4</b>	0	1
Potassium	ppm	ASTM D5185m >20	<1	<1	0
Water	%	ASTM D6304 >55	<b>0.785</b>	44.6	41.0
ppm Water	ppm	ASTM D6304 >55000	<b>7850</b>	446000	410000






## FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	---	10444	260
Particles >6µm	ASTM D7647 >1300	---	5690	142
Particles >14µm	ASTM D7647 >160	---	968	24
Particles >21µm	ASTM D7647 >40	---	326	8
Particles >38µm	ASTM D7647 >10	---	50	1
Particles >71µm	ASTM D7647 >3	---	5	0
Oil Cleanliness	ISO 4406 (c) >19/17/14	---	21/20/17	15/14/12

## FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045 3.63	<b>0.15</b>	---	3.753


# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	▲ MODER	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	▲ LAYRD	▲ LAYRD	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>55	NEG	0.2%
Free Water	scalar	*Visual	◆ 10.0	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
pH	Scale 0-14	ASTM D1287	---	7.00	9.00
Visc @ 40°C	cSt	ASTM D445	46	45.14	43.9

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : ST37295 **Received** : 16 Feb 2022  
**Lab Number** : 05470209 **Diagnosed** : 18 Feb 2022  
**Unique Number** : 9854422 **Diagnostician** : Jonathan Hester  
**Test Package** : IND 2 ( Additional Tests: KF, pH, ReserveAlk )

**KOBE WIELAND COPPER PRODUCTS**  
 3990 HWY. 311  
 PINE HALL, NC  
 US 27042  
 Contact: NEAL SHINAULT  
 NEAL.SHINAULT@WIELAND.COM  
 T: (336)604-1498  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)