


# **OIL ANALYSIS REPORT**



**VIS DEBRIS** 



# KAESER 7005333 (S/N 1195)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

## **DIAGNOSIS**

#### Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

#### Wear

All component wear rates are normal.

#### Contamination

Moderate concentration of visible dirt/debris present in the oil.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Jun2021	Jan 2022		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC94625	KC93257	
Sample Date		Client Info		25 Jan 2022	09 Jun 2021	
Machine Age	hrs	Client Info		10932	7457	
Oil Age	hrs	Client Info		3400	0	
Oil Changed		Client Info		Not Changd	Changed	
Sample Status				ABNORMAL	ATTENTION	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	2	2	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	<1	<1	
Aluminum	ppm	ASTM D5185m	>10	1	<1	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	5	5	
Tin	ppm	ASTM D5185m	>10	0	0	
Antimony	ppm	ASTM D5185m		0	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		3	11	
Barium	ppm	ASTM D5185m	90	3	10	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	<1	
Magnesium	ppm	ASTM D5185m	90	65	44	
Calcium	ppm	ASTM D5185m	2	<1	<1	
Phosphorus	ppm	ASTM D5185m		3	2	
Zinc	ppm	ASTM D5185m		2	3	
CONTAMINANTS	}	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2	0	
Sodium	ppm	ASTM D5185m		27	14	
Potassium	ppm	ASTM D5185m	>20	5	2	
Water	%	ASTM D6304	>0.05	0.015	0.025	
ppm Water	ppm	ASTM D6304	>500	152.6	255.4	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647			6044	
Particles >6µm		ASTM D7647	>1300		<b>1</b> 497	
Particles >14µm		ASTM D7647	>80		68	
Particles >21µm		ASTM D7647	>20		15	
Particles >38µm		ASTM D7647	>4		0	
Particles >71µm		ASTM D7647	>3		0	
Oil Cleanliness		ISO 4406 (c)	>/17/13		<b>1</b> 8/13	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	ma 1/011/a	ACTM DOOM	0.4	0.31	0.350	

Acid Number (AN)


mg KOH/g ASTM D8045 0.4

0.350

0.31



## **OIL ANALYSIS REPORT**







Certificate L2367

Laboratory Sample No. Lab Number **Unique Number** 

Test Package

: KC94625 : 05476914 : 9866128 : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : 24 Feb 2022 Recieved Diagnosed : 25 Feb 2022 : Don Baldridge Diagnostician

MCDANEL ADVANCED CERAMICS 510 NINTH AVE

BEAVER FALLS, PA US 15010

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: