




PROBLEM SUMMARY

Sample Rating Trend





WATER



Area
BLEACH O2
 Machine Id
METSO BX025 PRE02 PRESS NW (S/N 0661-03-02-040-040-090)
 Component
Bearing
 Fluid
NOT GIVEN (4 GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check for the source of water entry. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	SEVERE	NORMAL
Iron	ppm	ASTM D5185m	>20	▲ 32	20	7
Nickel	ppm	ASTM D5185m	>20	▲ 20	13	6
Water	%	ASTM D6304	>2	▲ 2.09	● 4.04	---
ppm Water	ppm	ASTM D6304		▲ 20900	● 40400	---
Emulsified Water	scalar	*Visual	>2	▲ 0.2%	● 0.2%	NEG

Customer Id: INTRIERP
 Sample No.: WC0625255
 Lab Number: 05477074
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Jonathan Hester +1 919-379-4092 x4092
jhester@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Check Water Access	MISSED	Apr 05 2022	?	We advise that you check for the source of water entry.

HISTORICAL DIAGNOSIS

31 Jan 2022 Diag: Doug Bogart

WATER



We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component. We recommend an early resample to monitor this condition. Please note that the oil was too thick and contaminated to perform an accurate viscosity test. All component wear rates are normal. There is a high concentration of water present in the oil. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid.

view report



29 Oct 2021 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



28 Jul 2021 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Area
BLEACH O2
 Machine Id
METSO BX025 PRE02 PRESS NW (S/N 0661-03-02-040-040-090)
 Component
Bearing
 Fluid
NOT GIVEN (4 GAL)

DIAGNOSIS

Recommendation

We advise that you check for the source of water entry. Resample at the next service interval to monitor.

Wear

The nickel level is abnormal. All other component wear rates are normal.

Contamination

There is a moderate concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0625255	WC0625267	WC0625273
Sample Date	Client Info		21 Feb 2022	31 Jan 2022	29 Oct 2021
Machine Age	mls	Client Info	0	0	0
Oil Age	mls	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	SEVERE	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >20	▲ 32	20	7
Chromium	ppm	ASTM D5185m >20	5	3	1
Nickel	ppm	ASTM D5185m >20	▲ 20	13	6
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	<1	<1	0
Aluminum	ppm	ASTM D5185m >20	0	<1	0
Lead	ppm	ASTM D5185m >20	0	0	<1
Copper	ppm	ASTM D5185m >20	9	5	3
Tin	ppm	ASTM D5185m >20	0	<1	<1
Antimony	ppm	ASTM D5185m	0	0	<1
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	<1	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	4	1	0
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	<1	<1	<1
Manganese	ppm	ASTM D5185m	<1	<1	0
Magnesium	ppm	ASTM D5185m	<1	0	<1
Calcium	ppm	ASTM D5185m	17	10	7
Phosphorus	ppm	ASTM D5185m	67	52	35
Zinc	ppm	ASTM D5185m	13	4	3
Sulfur	ppm	ASTM D5185m	11515	9220	7449





CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	9	7	4
Sodium	ppm	ASTM D5185m	31	15	3
Potassium	ppm	ASTM D5185m >20	2	0	1
Water	%	ASTM D6304 >2	▲ 2.09	4.04	---
ppm Water	ppm	ASTM D6304	▲ 20900	40400	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.37	0.351	0.357


OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	LIGHT	NONE	VLITE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	▲ MODER	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	THICK	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>2	▲ 0.2%	● 0.2%	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	1500	3802	1463

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0625255 **Received** : 24 Feb 2022
Lab Number : 05477074 **Diagnosed** : 28 Feb 2022
Unique Number : 9866288 **Diagnostician** : Jonathan Hester
Test Package : IND 2 (Additional Tests: KF)

INTERNATIONAL PAPER
 865 JOHN L REGEL RD
 RIEGELWOOD, NC
 US 28456
 Contact: Zach Lizana
 zachary.lizana@ipaper.com
 T: (910)362-4775
 F:

Certificate L2367
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)