




# OIL ANALYSIS REPORT

Sample Rating Trend



**WATER**



Area  
**97**  
Machine Id  
**[97] A97 Fan 901**  
Component  
**Center Gearbox**  
Fluid  
**GEAR LIFE 150 (5 GAL)**

## DIAGNOSIS

### ▲ Recommendation

No corrective action is recommended at this time. We recommend an early resample to monitor this condition.

### ▲ Wear

Gear wear is indicated.

### ▲ Contamination

Appearance is milky. There is a trace of moisture present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>HPL0000084</b>	HPL0000073	HPL0000045
Sample Date	Client Info	<b>23 Feb 2022</b>	17 Nov 2021	13 Aug 2021
Machine Age	hrs	<b>0</b>	0	0
Oil Age	hrs	<b>350</b>	200	50
Oil Changed	Client Info	<b>Not Chngd</b>	Not Chngd	Changed
Sample Status		<b>ABNORMAL</b>	SEVERE	SEVERE

## WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >200	<b>▲ 265</b>	▲ 267	165
Chromium	ppm	ASTM D5185m >10	<b>2</b>	2	1
Nickel	ppm	ASTM D5185m	<b>2</b>	<1	<1
Titanium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Silver	ppm	ASTM D5185m	<b>1</b>	<1	<1
Aluminum	ppm	ASTM D5185m >25	<b>10</b>	11	8
Lead	ppm	ASTM D5185m >50	<b>5</b>	5	4
Copper	ppm	ASTM D5185m >200	<b>&lt;1</b>	<1	<1
Tin	ppm	ASTM D5185m >10	<b>0</b>	<1	<1
Antimony	ppm	ASTM D5185m	<b>18</b>	30	35
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	<1	<1

## ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	<b>&lt;1</b>	20	20
Barium	ppm	ASTM D5185m	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Manganese	ppm	ASTM D5185m	<b>4</b>	3	2
Magnesium	ppm	ASTM D5185m	<b>28</b>	24	16
Calcium	ppm	ASTM D5185m	<b>62</b>	80	49
Phosphorus	ppm	ASTM D5185m	<b>153</b>	146	152
Zinc	ppm	ASTM D5185m	<b>0</b>	<1	3
Sulfur	ppm	ASTM D5185m	<b>17854</b>	19578	17519

## CONTAMINANTS


method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >50	<b>20</b>	30	20
Sodium	ppm	ASTM D5185m	<b>10</b>	4	1
Potassium	ppm	ASTM D5185m >20	<b>4</b>	2	1
Water	%	ASTM D6304 >0.2	<b>▲ 0.183</b>	1.14	▲ 0.536
ppm Water	ppm	ASTM D6304 >2000	<b>▲ 1830</b>	11400	▲ 5360

## FLUID DEGRADATION


method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.40</b>	0.364	0.419

# OIL ANALYSIS REPORT


### ▲ Ferrous Alloys




### ▲ Water (KF)



### Acid Number



### Viscosity @ 40°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	▲ MILKY	▲ MILKY
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	0.2%	0.2%
Free Water	scalar	*Visual	NEG	NEG	1.0


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	153	152	151

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------


Color	no image	no image	no image
Bottom	no image	no image	no image

### GRAPHS


#### ▲ Iron (ppm)




#### Aluminum (ppm)




#### Copper (ppm)




#### Viscosity @ 40°C




#### Lead (ppm)




#### Chromium (ppm)



#### Silicon (ppm)



#### ▲ Water



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : HPL0000084 **Received** : 01 Mar 2022  
**Lab Number** : 05480543 **Diagnosed** : 03 Mar 2022  
**Unique Number** : 9869757 **Diagnostician** : Jonathan Hester  
**Test Package** : MOB 2 ( Additional Tests: KF )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**KENSING**  
 2525 S KENSINGTON RD  
 KANKAKEE, IL  
 US 60901

Contact: TIM HUBERT  
 timothy.hubert@kensingsolutions.com

T: (815)939-8918

F: x: