PROBLEM SUMMARY

Sample Rating Trend



WATER

Machine Id
FRICK FRICK B
Component
Screw Compressor
Fluid
NOT GIVEN (--- GAL)

COMPONENT CONDITION SUMMARY

Water



Particle Trend



RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status				**ABNORMAL**	ABNORMAL	ABNORMAL
Water	%	ASTM D6304	>0.1	▲ **0.279**	▲ 0.358	▲ 0.251
ppm Water	ppm	ASTM D6304	>1000	▲ **2790.1**	▲ 3589.6	▲ 2511.2
Particles >4µm		ASTM D7647	>10000	▲ **31215**	▲ 79723	▲ 85222
Particles >6µm		ASTM D7647	>2500	▲ **7207**	▲ 25980	▲ 25315
Particles >14µm		ASTM D7647	>320	▲ **566**	▲ 1375	▲ 1768
Particles >21µm		ASTM D7647	>80	▲ **138**	▲ 330	▲ 546
Oil Cleanliness		ISO 4406 (c)	>20/18/15	▲ **22/20/16**	▲ 23/22/18	▲ 24/22/18

Customer Id: GARROW
Sample No.: TO50000457
Lab Number: 05535247
Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:
Jonathan Hester +1 919-379-4092 x4092
jhester@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	MISSED	May 05 2022	?	We recommend you service the filters on this component.

HISTORICAL DIAGNOSIS

27 Jan 2022 Diag: Jonathan Hester

WATER

We recommend you service the filters on this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

03 Oct 2021 Diag: Doug Bogart

WATER

We recommend you service the filters on this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

OIL ANALYSIS REPORT

Sample Rating Trend



WATER

Machine Id
FRICK FRICK B
Component
Screw Compressor
Fluid
NOT GIVEN (--- GAL)

DIAGNOSIS

Recommendation
We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear
All component wear rates are normal.

Contamination
There is a high amount of particulates present in the oil. There is a light concentration of water present in the oil.

Fluid Condition
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**TO50000457**	TO50000454	TO50000452
Sample Date		Client Info		**22 Feb 2022**	27 Jan 2022	03 Oct 2021
Machine Age	hrs	Client Info		**0**	0	0
Oil Age	hrs	Client Info		**0**	0	0
Oil Changed		Client Info		**N/A**	N/A	N/A
Sample Status				**ABNORMAL**	ABNORMAL	ABNORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>60	**0**	0	<1
Chromium	ppm	ASTM D5185m	>4	**0**	0	0
Nickel	ppm	ASTM D5185m		**0**	0	<1
Titanium	ppm	ASTM D5185m		**0**	0	0
Silver	ppm	ASTM D5185m		**0**	0	1
Aluminum	ppm	ASTM D5185m	>5	**0**	0	<1
Lead	ppm	ASTM D5185m	>10	**0**	0	<1
Copper	ppm	ASTM D5185m	>30	**0**	0	<1
Tin	ppm	ASTM D5185m	>15	**<1**	<1	<1
Antimony	ppm	ASTM D5185m		**---**	---	<1
Vanadium	ppm	ASTM D5185m		**0**	0	<1
Cadmium	ppm	ASTM D5185m		**0**	0	<1

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		**2**	<1	<1
Barium	ppm	ASTM D5185m		**0**	0	0
Molybdenum	ppm	ASTM D5185m		**0**	0	<1
Manganese	ppm	ASTM D5185m		**0**	0	<1
Magnesium	ppm	ASTM D5185m		**0**	0	<1
Calcium	ppm	ASTM D5185m		**0**	0	<1
Phosphorus	ppm	ASTM D5185m		**11**	7	6
Zinc	ppm	ASTM D5185m		**0**	0	0
Sulfur	ppm	ASTM D5185m		**1055**	1247	756

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	**23**	30	24
Sodium	ppm	ASTM D5185m		**0**	0	1
Potassium	ppm	ASTM D5185m	>20	**1**	1	1
Water	%	ASTM D6304	>0.1	▲ **0.279**	▲ 0.358	▲ 0.251
ppm Water	ppm	ASTM D6304	>1000	▲ **2790.1**	▲ 3589.6	▲ 2511.2

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	▲ **31215**	▲ 79723	▲ 85222
Particles >6µm		ASTM D7647	>2500	▲ **7207**	▲ 25980	▲ 25315
Particles >14µm		ASTM D7647	>320	▲ **566**	▲ 1375	▲ 1768
Particles >21µm		ASTM D7647	>80	▲ **138**	▲ 330	▲ 546
Particles >38µm		ASTM D7647	>20	**2**	9	▲ 22
Particles >71µm		ASTM D7647	>4	**0**	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	▲ **22/20/16**	▲ 23/22/18	▲ 24/22/18

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		**0.305**	0.206	0.822

OIL ANALYSIS REPORT

Water



Particle Trend



Viscosity @ 100°C



Acid Number



Viscosity @ 40°C



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	**NONE**	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Precipitate	scalar	*Visual	NONE	**NONE**	NONE	NONE
Silt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Debris	scalar	*Visual	NONE	**LIGHT**	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Appearance	scalar	*Visual	NORML	**NORML**	NORML	NORML
Odor	scalar	*Visual	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	**NEG**	NEG	NEG
Free Water	scalar	*Visual		**NEG**	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445		**109**	110	107
Visc @ 100°C	cSt	ASTM D445		**19.1**	19.3	19.03
Viscosity Index (VI)	Scale	ASTM D2270		**197**	197	199

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS

Ferrous Alloys



Non-ferrous Metals



Viscosity @ 40°C



Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : TO50000457 **Received** : 03 May 2022
Lab Number : 05535247 **Diagnosed** : 05 May 2022
Unique Number : 9959536 **Diagnostician** : Jonathan Hester
Test Package : IND 2 (Additional Tests: KF, KV100, PrtCount, VI)

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

GARLAND RENEWABLES
3175 ELM GROVE RD
ROWLETT, TX
US 75089
Contact: DUSTIN FRY
dustin@morrowrenew.com
T:
F: