




OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Area
GUAY SON [CONHER]
 Machine Id
Base Line IBACO XTRA REV 15W-40
 Component
New (Unused) Oil
 Fluid
Xtra Rev 15W-40 (--- GAL)

DIAGNOSIS

Recommendation

This is a baseline read-out on the submitted sample. (Customer Sample Comment: Batch #22080)

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			KL0010076	KL0010077	---
Sample Date	Client Info			10 May 2022	10 May 2022	---
Machine Age	hrs Client Info			0	0	---
Oil Age	hrs Client Info			0	0	---
Oil Changed	Client Info			N/A	N/A	---
Sample Status				NORMAL	NORMAL	---

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m		1	1	---
Chromium	ppm	ASTM D5185m		<1	<1	---
Nickel	ppm	ASTM D5185m		<1	<1	---
Titanium	ppm	ASTM D5185m		0	0	---
Silver	ppm	ASTM D5185m		1	2	---
Aluminum	ppm	ASTM D5185m		2	2	---
Lead	ppm	ASTM D5185m		<1	<1	---
Copper	ppm	ASTM D5185m		0	<1	---
Tin	ppm	ASTM D5185m		<1	<1	---
Vanadium	ppm	ASTM D5185m		0	0	---
Cadmium	ppm	ASTM D5185m		<1	<1	---

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		467	440	---
Barium	ppm	ASTM D5185m		0	0	---
Molybdenum	ppm	ASTM D5185m		119	107	---
Manganese	ppm	ASTM D5185m		<1	<1	---
Magnesium	ppm	ASTM D5185m		554	482	---
Calcium	ppm	ASTM D5185m		1463	1370	---
Phosphorus	ppm	ASTM D5185m		866	795	---
Zinc	ppm	ASTM D5185m		1016	925	---
Sulfur	ppm	ASTM D5185m		2702	2515	---






CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m		8	7	---
Sodium	ppm	ASTM D5185m		<1	<1	---
Potassium	ppm	ASTM D5185m	>20	1	<1	---
Water	%	ASTM D6304		NEG	NEG	---

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		10266	10798	---
Particles >6µm		ASTM D7647	>1300	1125	1048	---
Particles >14µm		ASTM D7647	>160	27	19	---
Particles >21µm		ASTM D7647	>40	3	2	---
Particles >38µm		ASTM D7647	>10	0	0	---
Particles >71µm		ASTM D7647	>3	0	0	---
Oil Cleanliness		ISO 4406 (c)	>17/14	17/12	17/11	---

FLUID DEGRADATION		method	limit/base	current	history1	history2
Base Number (BN)	mg KOH/g	ASTM D2896		8.83	8.69	---




OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	NEG	NEG	---
Free Water	scalar	*Visual	NEG	NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	107	102	---
Visc @ 100°C	cSt	ASTM D445	14.52	14.33	---
Viscosity Index (VI)	Scale	ASTM D2270	139	144	---

SAMPLE IMAGES



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KL0010076 **Received** : 20 May 2022
Lab Number : 05550672 **Diagnosed** : 25 May 2022
Unique Number : 9985039 **Diagnostician** : Jonathan Hester
Test Package : MOB 2 (Additional Tests: FT-IR, ICP-NewOil, KF, KV100, PrtCount, TBN,

CONOR
 JUAREZ 348
 HERMOSILLO,
 MX 83140
 Contact: EDUARDO GARCIA
 egarcia.comsa@gmail.com
 T: (526)622-1581 x:81
 F: x:

Certificate L2367
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)