




# PROBLEM SUMMARY

Sample Rating Trend





**WEAR**



Area  
**BEEBE [200005316]**  
 Machine Id  
**28WEA82333**

Component  
**Wind Turbine Gearbox**  
 Fluid  
**CASTROL OPTIGEAR SYNTHETIC X 320 (4 LTR)**

## COMPONENT CONDITION SUMMARY



## RECOMMENDATION

No corrective action is recommended at this time. We recommend an early resample to monitor this condition.

## PROBLEMATIC TEST RESULTS

Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL	
PQ	ASTM D8184	>80	<b>▲ 128</b>	111	108	
Iron	ppm	ASTM D5185m	>150	<b>▲ 364</b>	▲ 261	▲ 262

Customer Id: NORBEE  
 Sample No.: NX05568725  
 Lab Number: 05568725  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Angela Borella +1 800-237-1369  
[angela.borella@wearcheckusa.com](mailto:angela.borella@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Resample	---	---	?	We recommend an early resample to monitor this condition.

## HISTORICAL DIAGNOSIS

### 20 Aug 2021 Diag: Jonathan Hester

#### WEAR



No corrective action is recommended at this time. We recommend an early resample to monitor this condition. Gear wear is indicated. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



### 16 Jul 2021 Diag: Jonathan Hester

#### WEAR



No corrective action is recommended at this time. We recommend an early resample to monitor this condition. Gear wear is indicated. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



### 07 Jun 2020 Diag: Jonathan Hester

#### WEAR



No corrective action is recommended at this time. We recommend an early resample to monitor this condition. Gear wear is indicated. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


[view report](#)





# OIL ANALYSIS REPORT

Sample Rating Trend



**WEAR**



Area  
**BEEBE [200005316]**  
 Machine Id  
**28WEA82333**

Component  
**Wind Turbine Gearbox**  
 Fluid  
**CASTROL OPTIGEAR SYNTHETIC X 320 (4 LTR)**

## DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. We recommend an early resample to monitor this condition.

### Wear

Gear wear is indicated.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>NX05568725</b>	NX004293	NX005676
Sample Date	Client Info		<b>18 May 2022</b>	20 Aug 2021	16 Jul 2021
Machine Age	hrs	Client Info	<b>68227</b>	0	62184
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## WEAR METALS

	method	limit/base	current	history1	history2	
PQ	ASTM D8184	>80	<b>▲ 128</b>	111	108	
Iron	ppm	ASTM D5185m	>150	<b>▲ 364</b>	<b>▲ 261</b>	<b>▲ 262</b>
Chromium	ppm	ASTM D5185m	>5	<b>3</b>	2	2
Nickel	ppm	ASTM D5185m	>10	<b>&lt;1</b>	1	<1
Titanium	ppm	ASTM D5185m		<b>0</b>	0	0
Silver	ppm	ASTM D5185m		<b>0</b>	<1	<1
Aluminum	ppm	ASTM D5185m	>10	<b>&lt;1</b>	0	0
Lead	ppm	ASTM D5185m	>20	<b>0</b>	<1	<1
Copper	ppm	ASTM D5185m	>50	<b>1</b>	<1	<1
Tin	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Antimony	ppm	ASTM D5185m		<b>---</b>	0	0
Vanadium	ppm	ASTM D5185m		<b>0</b>	<1	<1
Cadmium	ppm	ASTM D5185m		<b>0</b>	<1	<1

## ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		<b>17</b>	<1	<1
Barium	ppm	ASTM D5185m		<b>2</b>	0	0
Molybdenum	ppm	ASTM D5185m	1150	<b>762</b>	750	772
Manganese	ppm	ASTM D5185m		<b>3</b>	2	2
Magnesium	ppm	ASTM D5185m		<b>44</b>	45	47
Calcium	ppm	ASTM D5185m	2000	<b>1569</b>	1553	1592
Phosphorus	ppm	ASTM D5185m	400	<b>358</b>	337	350
Zinc	ppm	ASTM D5185m	0	<b>21</b>	18	19
Sulfur	ppm	ASTM D5185m	1850	<b>1752</b>	1643	1715

## CONTAMINANTS






	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>50	<b>14</b>	11	11
Sodium	ppm	ASTM D5185m	>20	<b>9</b>	6	6
Potassium	ppm	ASTM D5185m	>20	<b>0</b>	<1	<1
Water	%	ASTM D6304	>0.05	<b>0.017</b>	0.034	0.047
ppm Water	ppm	ASTM D6304	>500	<b>170.3</b>	346.0	472.5

## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		<b>1084</b>	6112	1452
Particles >6µm	ASTM D7647	>2500	<b>290</b>	201	196
Particles >14µm	ASTM D7647	>320	<b>36</b>	7	8
Particles >21µm	ASTM D7647	>80	<b>10</b>	2	3
Particles >38µm	ASTM D7647	>20	<b>1</b>	0	1
Particles >71µm	ASTM D7647	>4	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>--/18/15	<b>17/15/12</b>	20/15/10	18/15/10



# OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.6	<b>0.421</b>	0.415	0.088






VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	<b>NEG</b>	NEG	NEG
Free Water	scalar	*Visual		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	320	<b>311</b>	309	313

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : NX05568725 **Received** : 14 Jun 2022  
**Lab Number** : 05568725 **Diagnosed** : 15 Jun 2022  
**Unique Number** : 10013125 **Diagnostician** : Angela Borella  
**Test Package** : IND 2 ( Additional Tests: KF, PQ, PrtCount )

**NORDEX USA - BEEBE**  
 1200 S COUNTY FARM RD  
 ITHACA, MI  
 US 48847  
 Contact: TUCKER WITT  
 tucker.witt@constellation.com  
 T:  
 F: (312)386-7102

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)