


Machine Id  
**VILTER VILTER**


Component  
**Screw Compressor**

Fluid  
**TULCO LUBSOIL LPG WI 100 (150 GAL)**



## COMPONENT CONDITION SUMMARY

### ▲ Particle Trend



## RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL
Particles >4µm	ASTM D7647	>10000	▲ <b>29378</b>	▲ 90065	▲ 114551
Particles >6µm	ASTM D7647	>2500	▲ <b>5530</b>	▲ 20151	▲ 28304
Particles >14µm	ASTM D7647	>320	▲ <b>382</b>	▲ 1427	▲ 1671
Particles >21µm	ASTM D7647	>80	▲ <b>83</b>	▲ 424	▲ 320
Oil Cleanliness	ISO 4406 (c)	>20/18/15	▲ <b>22/20/16</b>	▲ 24/22/18	▲ 24/22/18

Customer Id: CAMFORAR  
Sample No.: TO70000005  
Lab Number: 05573176  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Don Baldrige +1  
[don.b505@comcast.net](mailto:don.b505@comcast.net)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	MISSED	Jul 13 2022	?	We recommend you service the filters on this component if applicable.

## HISTORICAL DIAGNOSIS

### 02 May 2022 Diag: Jonathan Hester

ISO



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 04 Apr 2022 Diag: Don Baldrige

ISO



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 07 Feb 2022 Diag: Doug Bogart

VISUAL METAL




We recommend you service the filters on this component. We advise that you inspect for the source(s) of wear. Resample at the next service interval to monitor. We were unable to perform a particle count due to metal particles present in this sample. An increase in the iron level is noted. Moderate concentration of visible metal present. No other contaminants were detected in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



Machine Id  
**VILTER VILTER**  
Component  
**Screw Compressor**  
Fluid  
**TULCO LUBSOIL LPG WI 100 (150 GAL)**



## DIAGNOSIS

### Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>TO70000005</b>	TO70000004	TO70000002
Sample Date	Client Info	<b>02 Jun 2022</b>	02 May 2022	04 Apr 2022
Machine Age	wks Client Info	<b>0</b>	0	0
Oil Age	wks Client Info	<b>0</b>	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m >60	<b>1</b>	2	5
Chromium	ppm ASTM D5185m >4	<b>0</b>	0	<1
Nickel	ppm ASTM D5185m	<b>0</b>	0	<1
Titanium	ppm ASTM D5185m	<b>0</b>	0	0
Silver	ppm ASTM D5185m	<b>0</b>	0	<1
Aluminum	ppm ASTM D5185m >5	<b>&lt;1</b>	0	<1
Lead	ppm ASTM D5185m >10	<b>0</b>	<1	<1
Copper	ppm ASTM D5185m >30	<b>0</b>	0	<1
Tin	ppm ASTM D5185m >15	<b>&lt;1</b>	<1	1
Antimony	ppm ASTM D5185m	<b>---</b>	---	---
Vanadium	ppm ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m 0	<b>3</b>	4	2
Barium	ppm ASTM D5185m	<b>0</b>	0	0
Molybdenum	ppm ASTM D5185m 0	<b>0</b>	0	0
Manganese	ppm ASTM D5185m	<b>0</b>	0	<1
Magnesium	ppm ASTM D5185m 0	<b>&lt;1</b>	0	0
Calcium	ppm ASTM D5185m	<b>2</b>	0	1
Phosphorus	ppm ASTM D5185m 0	<b>4</b>	6	11
Zinc	ppm ASTM D5185m 0	<b>3</b>	0	0
Sulfur	ppm ASTM D5185m 0	<b>1185</b>	745	877

## CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >50	<b>25</b>	24	22
Sodium	ppm ASTM D5185m	<b>0</b>	0	0
Potassium	ppm ASTM D5185m >20	<b>0</b>	0	<1
Water	% ASTM D6304 >2.26	<b>0.386</b>	0.343	0.192
ppm Water	ppm ASTM D6304 >22600	<b>3865.4</b>	3431.9	1929.5

## FLUID CLEANLINESS


method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	<b>▲ 29378</b>	▲ 90065	▲ 114551
Particles >6µm	ASTM D7647 >2500	<b>▲ 5530</b>	▲ 20151	▲ 28304
Particles >14µm	ASTM D7647 >320	<b>▲ 382</b>	▲ 1427	▲ 1671
Particles >21µm	ASTM D7647 >80	<b>▲ 83</b>	▲ 424	▲ 320
Particles >38µm	ASTM D7647 >20	<b>5</b>	▲ 22	▲ 25
Particles >71µm	ASTM D7647 >4	<b>0</b>	0	1
Oil Cleanliness	ISO 4406 (c) >20/18/15	<b>▲ 22/20/16</b>	▲ 24/22/18	▲ 24/22/18

## FLUID DEGRADATION


method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D8045	<b>0.357</b>	0.259	1.09

# OIL ANALYSIS REPORT


## Particle Trend




## Water




## Viscosity @ 100°C



## Water



## Viscosity @ 100°C




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	LIGHT	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>2.26	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	113	106	108
Visc @ 100°C	cSt	ASTM D445	19	18.3	18.6
Viscosity Index (VI)	Scale	ASTM D2270	189	192	193

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------


Color




Bottom

## GRAPHS


### Ferrous Alloys




### Non-ferrous Metals




### Viscosity @ 40°C



### Particle Count



### Acid Number



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : TO70000005 **Received** : 21 Jun 2022  
**Lab Number** : 05573176 **Diagnosed** : 22 Jun 2022  
**Unique Number** : 10022593 **Diagnostician** : Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: KF, KV100, PrtCount, VI )

**CAMBRIAN ENERGY-SOUTH TEX FT. SMITH TREATERS**  
 5950 COMMERCE RD  
 FORT SMITH, AR  
 US 72916  
 Contact: DUSTIN FRY  
 dustin@morrowenergy.com  
 T: (479)221-7571  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)