

# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# **KAESER 7352116**

Component Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

## Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.


## **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				Jun2022		
CAMPLE INFORM	AATION		11		la faction and	h'-1 0
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCP51133		
Sample Date		Client Info		20 Jun 2022		
Machine Age	hrs	Client Info		5260		
Oil Age	hrs	Client Info		3400		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m	>3	0		
Titanium	ppm	ASTM D5185m	>3	0		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum	ppm	ASTM D5185m	>10	<1		
Lead	ppm	ASTM D5185m	>10	0		
Copper	ppm	ASTM D5185m		<1		
Tin	ppm	ASTM D5185m	>10	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES	PP	method	limit/base	current	history1	history2
			IIIIIIIIIIII			
Boron	ppm	ASTM D5185m	00	2		
Barium	ppm	ASTM D5185m	90	32		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m	90	85		
Calcium	ppm	ASTM D5185m	2	4		
Phosphorus	ppm	ASTM D5185m		6		
Zinc	ppm	ASTM D5185m		4		
Sulfur	ppm	ASTM D5185m		20967		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1		
Sodium	ppm	ASTM D5185m		16		
Potassium	ppm	ASTM D5185m	>20	5		
Water	%	ASTM D6304	>0.05	0.032		
ppm Water	ppm	ASTM D6304	>500	320.6		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		486		
Particles >6µm		ASTM D7647	>1300	102		
Particles >14μm		ASTM D7647	>80	14		
Particles >21µm		ASTM D7647	>20	4		
Particles >38µm		ASTM D7647	>4	1		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	16/14/11		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.36		



## **OIL ANALYSIS REPORT**







Certificate 12367

Sample No. Lab Number

: KCP51133 : 05585113

Unique Number : 10039539

Received : 06 Jul 2022 **Tested** Diagnosed Test Package : IND 2 ( Additional Tests: KF, PrtCount )

: 07 Jul 2022

: 07 Jul 2022 - Doug Bogart

NEWNAN, GA US 30263 Contact: A. RIOMATH ariomath@mazon.com T:

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: