



# Machine Id 7187494 (S/N 1027) Component

Compressor Fluid KAESER SIGMA (OEM) S-460 (--- QTS)

# COMPONENT CONDITION SUMMARY



# RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

# PROBLEMATIC TEST RESULTS

THOBEEMINTIO TEO					
Sample Status			ABNORMAL	NORMAL	ABNORMAL
Particles >6µm	ASTM D7647	>1300	<u> </u>		
Particles >14µm	ASTM D7647	>80	🔺 2845		
Particles >21µm	ASTM D7647	>20	<u> </u>		
Particles >38µm	ASTM D7647	>4	<mark>/</mark> 99		
Oil Cleanliness	ISO 4406 (c)	>/17/13	<u> </u>		

Customer Id: GRAGREKCP Sample No.: KCP44144 Lab Number: 05586806 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

*To change component or sample information:* Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>



# **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

# HISTORICAL DIAGNOSIS

# 16 Mar 2022 Diag: Don Baldridge



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count on this sample.All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## 23 Aug 2021 Diag: Jonathan Hester



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report





# **OIL ANALYSIS REPORT**

# Sample Rating Trend ISO

Machine Id 7187494 (S/N 1027) Component Compressor

Fluid KAESER SIGMA (OEM) S-460 (--- QTS)

# DIAGNOSIS

# Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

# Wear

All component wear rates are normal.

# Contamination

There is a high amount of particulates present in the oil.

## Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	<b>IATION</b>	method	limit/base	current	history1	history2
Sample Number		Client Info		KCP44144	KCP45326	KC41537
Sample Date		Client Info		24 Jun 2022	16 Mar 2022	23 Aug 2021
Machine Age	hrs	Client Info		7408	6140	3861
Oil Age	hrs	Client Info		4718	3450	3861
Oil Changed		Client Info		Not Changd	Not Chanod	Changed
Sample Status				ABNORMAL	NORMAL	ABNORMAL
	_	method	limit/base	ourrent	history1	history2
				Guirent		0
Chromeium	ррп		10	<1	< 1	2
Chromium	ррп		>10	0	0	0
NICKEI	ppm	ASTM D5185m	>3	0	0	0
Filter	ppm	ASTM D5185m	>3	0	0	0
Sliver	ppm	ACTM DE105m	>2	0	<	U
Aluminum	ppm	ASTM D5185m	>10	<1	<	< 1
Lead	ppm	ASTM D5185m	>10	0	<1	0
Copper	ppm	ASTM D5185m	>50	2	2	4
i in	ppm	ASTM D5185m	>10	<1	<1	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		3	2	0
Barium	ppm	ASTM D5185m	90	85	83	95
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	1
Magnesium	ppm	ASTM D5185m	90	84	88	97
Calcium	ppm	ASTM D5185m	2	4	2	3
Phosphorus	ppm	ASTM D5185m		<1	3	6
Zinc	ppm	ASTM D5185m		1	0	0
Sulfur	ppm	ASTM D5185m		19512	16242	16914
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	<1
Sodium	ppm	ASTM D5185m		17	13	19
Potassium	ppm	ASTM D5185m	>20	2	<1	8
Water	%	ASTM D6304	>0.05	0.030	0.024	0.037
ppm Water	ppm	ASTM D6304	>500	308.0	249.0	379.7
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		16730		
Particles >6µm		ASTM D7647	>1300	<u> </u>		
Particles >14µm		ASTM D7647	>80	<u> </u>		
Particles >21µm		ASTM D7647	>20	<u> </u>		
Particles >38µm		ASTM D7647	>4	<b>4</b> 99		
Particles >71µm		ASTM D7647	>3	2		
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>A</b> 21/21/19		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	ma KOU/a		0.4	0.34	0.35	0.291

Report Id: GRAGREKCP [WUSCAR] 05586806 (Generated: 10/02/2023 10:18:01) Rev: 1

Contact/Location: J. TYSON - GRAGREKCP



# **OIL ANALYSIS REPORT**







VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	LIGHT	MODER	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE	A MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	44.4	44.7	45.5
SAMPLE IMAGES	6	method	limit/base	current	history1	history2
Color						



Bottom



Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: J. TYSON - GRAGREKCP