


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



 $^{\text{Machine Id}}_{6987206}$ (S/N 1132)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Oct2020	Jun2021 Aug202	Sep2021 Jan2022	Jul2022	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC93084	KC93080	KC98782
Sample Date		Client Info		06 Jul 2022	18 Jan 2022	18 Sep 2021
Machine Age	hrs	Client Info		20272	16981	14458
Oil Age	hrs	Client Info		0	16981	14458
Oil Changed		Client Info		Changed	Not Changd	Changed
Sample Status				NORMAL	ABNORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	<1	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	2	3
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	12	10	11
Tin	ppm	ASTM D5185m	>10	<1	0	0
Antimony	ppm	ASTM D5185m			0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	<1
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	90	1	4	<1
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		13	5	2
Zinc	ppm	ASTM D5185m		0	0	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	0
Sodium	ppm	ASTM D5185m		0	1	0
Potassium	ppm	ASTM D5185m	>20	<1	0	0
Water	%	ASTM D6304	>0.05	0.011	0.002	0.006
ppm Water	ppm	ASTM D6304	>500	115.7	19.8	69.9
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		862	16434	339
Particles >6µm		ASTM D7647	>1300	260	△ 5570	135
Particles >14µm		ASTM D7647	>80	12	490	5
Particles >21µm		ASTM D7647	>20	2	△ 93	2
Particles >38µm		ASTM D7647	>4	1	<u> </u>	0
Particles >71μm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/15/11	<u>^</u> 20/16	14/10
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
A atal Name to any (ANI)		AOTM D0045	0.4	0.50	0.47	0.404

Acid Number (AN)

mg KOH/g ASTM D8045 0.4

0.47

0.52

0.484



OIL ANALYSIS REPORT







Certificate L2367

Laboratory Sample No. Lab Number

: KC93084 : 05588278

Unique Number: 10047725 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 11 Jul 2022

Tested : 12 Jul 2022 : 13 Jul 2022 - Doug Bogart Diagnosed

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

800 PENNSYLVANIA AVE SALEM, OH

US 44460

VENTRA PLASTICS

Contact: A. MONTER amonter@flexngate.com

T:

F:

Contact/Location: A. MONTER - VENSALOH