

# **PROBLEM SUMMARY**

Sample Rating Trend

**WEAR** 


Machine Id **6929061 (S/N 1135)** 

Component

Compressor

KAESER SIGMA (OEM) FG-460 (--- GAL)

## **COMPONENT CONDITION SUMMARY**



### RECOMMENDATION

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC T	EST RE	RESULTS  ABNORMAL ABNORMAL NORMAL				
Sample Status				ABNORMAL	ABNORMAL	NORMAL
Aluminum	ppm	ASTM D5185m	>10	<b>14</b>	<u>15</u>	9

**Customer Id: EARATL** Sample No.: KCP51135 Lab Number: 05596506 Test Package: IND 2 To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

### **RECOMMENDED ACTIONS**

Action	Status	Date	Done By	Description
Change Fluid			?	Oil and filter change at the time of sampling has been noted.
Change Filter			?	Oil and filter change at the time of sampling has been noted.

### HISTORICAL DIAGNOSIS

### 18 Oct 2021 Diag: Jonathan Hester

#### WATER



We advise that you stop the unit and follow the water drain-off procedure for this component. The filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition. The aluminum level is abnormal. There is a light concentration of water present in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



### 02 Jul 2020 Diag: Angela Borella

#### NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





# **OIL ANALYSIS REPORT**

Sample Rating Trend

**WEAR** 

6929061 (S/N 1135)

Compressor

KAESER SIGMA (OEM) FG-460 (--- GAL)

## **DIAGNOSIS**

### Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

## Wear

The aluminum level is abnormal. All other component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Ju	2020	Oct2021 Jun 20	Det2021 Jun2022		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2	
Sample Number		Client Info		KCP51135	KCP38715	KCP10904	
Sample Date		Client Info		09 Jun 2022	18 Oct 2021	02 Jul 2020	
Machine Age	hrs	Client Info		3419	2482	1058	
Oil Age	hrs	Client Info		2400	1424	1058	
Oil Changed		Client Info		Changed	Not Changd	Changed	
Sample Status				ABNORMAL	ABNORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>50	6	6	3	
Chromium	ppm	ASTM D5185m	>10	0	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	0	
Silver	ppm	ASTM D5185m	>2	<1	<1	0	
Aluminum	ppm	ASTM D5185m	>10	<u> 14</u>	<b>△</b> 15	9	
Lead	ppm	ASTM D5185m	>10	0	<1	<1	
Copper	ppm	ASTM D5185m	>50	2	2	2	
Tin	ppm	ASTM D5185m	>10	<1	<1	0	
Antimony	ppm	ASTM D5185m			0	0	
Vanadium	ppm	ASTM D5185m		0	0	0	
Cadmium	ppm	ASTM D5185m		0	0	0	
ADDITIVES		method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		1	3	1	
Barium	ppm	ASTM D5185m		0	0	0	
Molybdenum	ppm	ASTM D5185m		0	0	0	
Manganese	ppm	ASTM D5185m		<1	<1	<1	
Magnesium	ppm	ASTM D5185m		1	2	0	
Calcium	ppm	ASTM D5185m		0	<1	0	
Phosphorus	ppm	ASTM D5185m	500	370	416	260	
Zinc	ppm	ASTM D5185m		232	172	81	
Sulfur	ppm	ASTM D5185m		2496	2194	4071	
CONTAMINANTS		method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>25	<1	<1	0	
Sodium	ppm	ASTM D5185m		0	5	0	
Potassium	ppm	ASTM D5185m	>20	<1	3	0	
Water	%	ASTM D6304	>0.05	0.010	<b>△</b> 0.207	0.006	
ppm Water	ppm	ASTM D6304	>500	105.3	▲ 2070	66.0	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2	
Particles >4µm		ASTM D7647		693	2247	4077	
Particles >6µm		ASTM D7647	>1300	204	724	815	
Particles >14µm		ASTM D7647	>80	23	32	18	
Particles >21µm		ASTM D7647	>20	5	4	4	
Particles >38µm		ASTM D7647	>4	1	0	0	
Particles >71µm		ASTM D7647	>3	0	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/15/12	17/12	17/11	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	1.5	0.81	0.806	0.789	



# **OIL ANALYSIS REPORT**

