




# PROBLEM SUMMARY

Sample Rating Trend



ISO




Machine Id  
**KAESER SK 15 5584421 (S/N 1915)**

Component  
**Compressor**  
 Fluid  
**KAESER SIGMA (OEM) M-460 (--- GAL)**

## COMPONENT CONDITION SUMMARY

▲ Particle Trend



## RECOMMENDATION

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ATTENTION	ATTENTION
Particles >6µm	ASTM D7647	>1300	▲ 5626	▲ 1315	▲ 1760
Particles >14µm	ASTM D7647	>80	▲ 680	75	▲ 155
Particles >21µm	ASTM D7647	>20	▲ 148	25	▲ 40
Particles >38µm	ASTM D7647	>4	▲ 10	0	0
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ 21/20/17	▲ 18/13	▲ 18/14

Customer Id: HIGWAT  
 Sample No.: KCP51564  
 Lab Number: 05597544  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Don Baldrige +1  
[don.b505@comcast.net](mailto:don.b505@comcast.net)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	Oil and filter change at the time of sampling has been noted.
Change Filter	---	---	?	Oil and filter change at the time of sampling has been noted.

## HISTORICAL DIAGNOSIS

### 07 Dec 2021 Diag: Jonathan Hester

ISO



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 13 Jan 2021 Diag: Jonathan Hester

ISO



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 14 Oct 2019 Diag: Angela Borella

NORMAL




Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id  
**KAESER SK 15 5584421 (S/N 1915)**

Component

**Compressor**

Fluid

**KAESER SIGMA (OEM) M-460 (--- GAL)**

**DIAGNOSIS**

**Recommendation**

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

**Wear**

All component wear rates are normal.

**Contamination**

There is a high amount of particulates present in the oil.

**Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

**SAMPLE INFORMATION**

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>KCP51564</b>	KCP43835	KCP28087
Sample Date	Client Info		<b>13 Jul 2022</b>	07 Dec 2021	13 Jan 2021
Machine Age	hrs	Client Info	<b>18230</b>	17119	16611
Oil Age	hrs	Client Info	<b>1111</b>	880	4
Oil Changed	Client Info		<b>Changed</b>	Changed	Not Changd
Sample Status			<b>ABNORMAL</b>	ATTENTION	ATTENTION

**WEAR METALS**

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<b>&lt;1</b>	1	0
Chromium	ppm	ASTM D5185m >10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m >3	<b>0</b>	0	<1
Titanium	ppm	ASTM D5185m >3	<b>0</b>	0	0
Silver	ppm	ASTM D5185m >2	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >10	<b>&lt;1</b>	<1	0
Lead	ppm	ASTM D5185m >10	<b>0</b>	0	<1
Copper	ppm	ASTM D5185m >50	<b>4</b>	5	9
Tin	ppm	ASTM D5185m >10	<b>&lt;1</b>	0	0
Antimony	ppm	ASTM D5185m	<b>---</b>	0	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

**ADDITIVES**

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	<b>3</b>	0	12
Barium	ppm	ASTM D5185m 90	<b>4</b>	1	0
Molybdenum	ppm	ASTM D5185m 0	<b>1</b>	0	0
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	<1	0
Magnesium	ppm	ASTM D5185m 100	<b>33</b>	35	13
Calcium	ppm	ASTM D5185m 0	<b>19</b>	0	0
Phosphorus	ppm	ASTM D5185m 0	<b>18</b>	2	4
Zinc	ppm	ASTM D5185m 0	<b>20</b>	16	44
Sulfur	ppm	ASTM D5185m 23500	<b>20547</b>	15990	19610

**CONTAMINANTS**

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<b>&lt;1</b>	0	<1
Sodium	ppm	ASTM D5185m	<b>8</b>	8	9
Potassium	ppm	ASTM D5185m >20	<b>&lt;1</b>	0	2
Water	%	ASTM D6304 >0.05	<b>0.032</b>	0.013	0.008
ppm Water	ppm	ASTM D6304 >500	<b>322.9</b>	137.8	88.4

**FLUID CLEANLINESS**


	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		<b>16154</b>	6723	5118
Particles >6µm	ASTM D7647	>1300	<b>▲ 5626</b>	▲ 1315	▲ 1760
Particles >14µm	ASTM D7647	>80	<b>▲ 680</b>	75	▲ 155
Particles >21µm	ASTM D7647	>20	<b>▲ 148</b>	25	▲ 40
Particles >38µm	ASTM D7647	>4	<b>▲ 10</b>	0	0
Particles >71µm	ASTM D7647	>3	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>--/17/13	<b>▲ 21/20/17</b>	▲ 18/13	▲ 18/14

**FLUID DEGRADATION**

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 1.0	<b>0.38</b>	0.332	0.332


# OIL ANALYSIS REPORT

## ▲ Particle Trend




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

## Water




FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	47.1	48.0






## SAMPLE IMAGES



## Acid Number



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KCP51564 **Received** : 21 Jul 2022  
**Lab Number** : 05597544 **Diagnosed** : 25 Jul 2022  
**Unique Number** : 10062024 **Diagnostician** : Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

**HIGH TECH TURNING CO**  
 16 BRIDGE ST  
 WATERTOWN, MA  
 US 02472  
 Contact: RON  
 ron@hightechturning.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)