

FUEL REPORT

Sample Rating Trend



Area [W55624] MTU 95010500032 Component

Diesel Fuel

Fluic No.2 DIESEL FUEL (LOW-SULPHUR) (1000 GAL)

Recommendation

All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel type.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

The water content is negligible. There is no Bacteria, Yeast and/or Fungus indicated in the sample. There is no indication of any contamination in the fuel.


Fuel Condition


Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

GAL)		Jur	2020	May2021 Jun2	022	
SAMPLE INFORM	NATION	method	limit/base	current	history1	history2
Sample Number Sample Date		Client Info Client Info		WC0633757 24 Jun 2022	WCDF01836 27 May 2021	WCDF01341 12 Jun 2020
Machine Age	hrs	Client Info		0	0	0
Sample Status				NORMAL	NORMAL	NORMAL
PHYSICAL PROP	PERTIES	method	limit/base	current	history1	history2
ASTM Color	scalar	*ASTM D1500		L5.5	L4.5	L5.5
Visc @ 40°C	cSt	ASTM D445	3.0	2.46	2.36	2.55
SULFUR CONTE	NT	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	250	14	36	6
Sulfur (UVF)	ppm	ASTM D5453		8	11	9
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0	0	0
Sodium	ppm	ASTM D5185m	<0.1	0	0	0
Potassium	ppm	ASTM D5185m	<0.1	0	0	6
Water	%	ASTM D6304	<0.05	0.003	0.005	0.003
ppm Water	ppm	ASTM D6304	<500	35.3	56.7	30.9
% Gasoline	%	*In-House	<0.50	0.0	0.0	0.0
% Biodiesel	%	*In-House	<20.0	1.7	1.9	1.7
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	15949		
Particles >6µm		ASTM D7647		3385		
Particles >14µm		ASTM D7647	>80	269		
Particles >21µm		ASTM D7647		93		
Particles >38µm		ASTM D7647	>4	3		
Particles >71µm Oil Cleanliness		ASTM D7647 ISO 4406 (c)		0 21/19/15		
HEAVY METALS		method	limit/base		history1	history2
Aluminum	nom	ASTM D5185m	<0.1	current 0	0	<1
Nickel	ppm ppm	ASTM D5185m	<0.1	0	0	< 1
Lead	ppm	ASTM D5185m	<0.1	0	0	0
Vanadium	ppm	ASTM D5185m	<0.1	0	0	0
Iron	ppm	ASTM D5185m	<0.1	0	0	<1
Calcium	ppm	ASTM D5185m	<0.1	0	1	0
Magnesium	ppm	ASTM D5185m	<0.1	0	0	<1
Phosphorus	ppm	ASTM D5185m		0	3	<1
Zinc	ppm	ASTM D5185m	<0.1	0	0	<1
SAMPLE IMAGES	5	method	limit/base	current	history1	history2
Color						no image
Bottom						no image
:22:22) Rev: 1				Contact/Locati	ion: BRANDON	RICE - NATRA



FUEL REPORT





ANARA CERECTIVE	Laboratory Sample No. Lab Number Unique Number	: WC0633757 : <mark>05600682</mark>	- 501 Madison Av Received Diagnosed Diagnostician	re., Cary, NC 27513 : 26 Jul 2022 : 01 Aug 2022 : Doug Bogart	NATIONAL POWER CORP 4541 PRESLYN DR RALEIGH, NC US 27616
Centificate 12367 To discuss this * - Denotes tes Statements of d	Contact: BRANDON RICE brandon.rice@natpow.com T: F: (919)790-9714				

Contact/Location: BRANDON RICE - NATRAL