




FUEL REPORT

Sample Rating Trend

NORMAL



Area
[2022-165]
 Machine Id
B760105119
 Component
Diesel Fuel
 Fluid
DISESEL FUEL No. 2 (--- GAL)

DIAGNOSIS

Recommendation

All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.

Contaminants

There is no Bacteria, Yeast and/or Fungus indicated in the sample. There is no indication of any contamination in the fuel.

Fuel Condition

The condition of the fuel is suitable for service. Sulfur value derived by ASTM D4294 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			WC0678305	WCDF01944	WCDF00554
Sample Date	Client Info			22 Jul 2022	02 Jul 2021	24 May 2018
Machine Age	hrs	Client Info		0	0	0
Sample Status				NORMAL	NORMAL	NORMAL

PHYSICAL PROPERTIES		method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298		0.839	0.835	0.842
Fuel Color	text	*Visual Screen		Red	Red	Red
ASTM Color	scalar	*ASTM D1500		L5.5	L5.5	L5.0
Visc @ 40°C	cSt	ASTM D445	4.1	2.48	2.39	2.44
Pensky-Martens Flash Point	°C	*PMCC Calculated		61	59	64

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		4	22	2
Sulfur (UVF)	ppm	ASTM D5453		12	8	9






DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86		165	165	165
5% Distillation Point	°C	ASTM D86		190	189	191
10% Distill Point	°C	ASTM D86		201	200	202
15% Distillation Point	°C	ASTM D86		210	207	211
20% Distill Point	°C	ASTM D86		218	215	219
30% Distill Point	°C	ASTM D86		231	229	234
40% Distill Point	°C	ASTM D86		245	242	248
50% Distill Point	°C	ASTM D86		259	256	262
60% Distill Point	°C	ASTM D86		273	270	276
70% Distill Point	°C	ASTM D86		289	285	291
80% Distill Point	°C	ASTM D86		305	302	307
85% Distillation Point	°C	ASTM D86		315	312	316
90% Distill Point	°C	ASTM D86		327	324	327
95% Distillation Point	°C	ASTM D86		345	340	343
Final Boiling Point	°C	ASTM D86		353	349	351
Distillation Residue	%	ASTM D86		1.4	1.4	1.4
Distillation Loss	%	ASTM D86		0.8	0.7	0.6

IGNITION QUALITY		method	limit/base	current	history1	history2
API Gravity		ASTM D7777		37.2	38.0	36.6
Cetane Index		ASTM D4737	<40.0	48.7	49.4	48.0

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0	0	5
Sodium	ppm	ASTM D5185m	<0.1	0	<1	0
Potassium	ppm	ASTM D5185m	<0.1	0	0	0
Water	%	ASTM D6304	<0.05	0.005	0.003	0.005
ppm Water	ppm	ASTM D6304	<500	57.0	35.4	50
% Gasoline	%	*In-House	<0.50	0.0	0.0	0.0
% Biodiesel	%	*In-House	<20.0	0.0	0.5	1.5



FUEL REPORT



FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	21643	---	---
Particles >6µm	ASTM D7647	>640	7588	---	---
Particles >14µm	ASTM D7647	>80	658	---	---
Particles >21µm	ASTM D7647	>20	161	---	---
Particles >38µm	ASTM D7647	>4	5	---	---
Particles >71µm	ASTM D7647	>3	0	---	---
Oil Cleanliness	ISO 4406 (c)	>18/16/13	22/20/17	---	---



HEAVY METALS	method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m <0.1	0	0	0
Nickel	ppm	ASTM D5185m <0.1	0	0	0
Lead	ppm	ASTM D5185m <0.1	0	0	0
Vanadium	ppm	ASTM D5185m <0.1	0	0	0
Iron	ppm	ASTM D5185m <0.1	0	0	0
Calcium	ppm	ASTM D5185m <0.1	0	5	0
Magnesium	ppm	ASTM D5185m <0.1	0	0	0
Phosphorus	ppm	ASTM D5185m <0.1	1	8	0
Zinc	ppm	ASTM D5185m <0.1	0	2	0

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

no image

no image

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0678305 **Received** : 27 Jul 2022
Lab Number : 05602450 **Tested** : 02 Aug 2022
Unique Number : 10071931 **Diagnosed** : 02 Aug 2022 - Doug Bogart
Test Package : DF-2 (Additional Tests: Fuel, Screen)

R.B. SERVICES INC
 1955 BURTON ROAD
 THOMASVILLE, NC
 US 27360
 Contact: PATSY BODENHEIMER
 rbservicesinc@northstate.net
 T: (336)841-6311
 F: x:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)