


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER SFC 110ST 4009201 (S/N 1017)

Compressor

KAESER SIGMA (OEM) M-460 (--- QTS)

Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Ma	[,] 2012	Apr2015 Aug20	22	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCP48365	KC48811	KC20069
Sample Date		Client Info		15 Aug 2022	08 Apr 2015	15 May 2012
Machine Age	hrs	Client Info		34154	18860	5385
Oil Age	hrs	Client Info		3000	0	5384
Oil Changed		Client Info		Changed	Changed	N/A
Sample Status				ATTENTION	ABNORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	<1	<1	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	1	0	0
Aluminum	ppm	ASTM D5185m	>10	2	0	<1
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m	>50	8	7	10
Tin	ppm	ASTM D5185m	>10	1	0	0
Antimony	ppm	ASTM D5185m			<1	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	<1	0	0
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	<1	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	100	0	<1	0
Calcium	ppm	ASTM D5185m	0	0	0	0
Phosphorus	ppm	ASTM D5185m	0	<1	3	1
Zinc	ppm	ASTM D5185m	0	0	1	24
Sulfur	ppm	ASTM D5185m	23500	10391	17210	17977
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	<1	0
Sodium	ppm	ASTM D5185m		0	0	<1
Potassium	ppm	ASTM D5185m	>20	0	0	6
Water	%	ASTM D6304	>0.05	0.003	0.007	0.004
ppm Water	ppm	ASTM D6304	>500	27.5	70	40
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		6165		64
Particles >6µm		ASTM D7647		1177		34
Particles >14µm		ASTM D7647	>80	81		5
Particles >21µm		ASTM D7647	>20	30		2
Particles >38µm		ASTM D7647	>4	2		0
Particles >71μm		ASTM D7647	>3	0		0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>20/17/14</u>		12/10
FLUID DEGRADA	TION					



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

Lab Number

: KCP48365 : 05628366 Unique Number: 10112887

Received **Tested** Diagnosed Test Package : IND 2 (Additional Tests: KF, PrtCount)

: 26 Aug 2022 : 29 Aug 2022

: 30 Aug 2022 - Angela Borella

US 94587 Contact: JEFFERY jeffery@westernallied.com T:

33210 CENTRAL AVE

UNION CITY, CA

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: