

# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id  
**8379922 (S/N 1332)**

Component  
**Compressor**

Fluid  
**KAESER SIGMA (OEM) M-460 (--- QTS)**

## DIAGNOSIS

### ▲ Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### ▲ Contamination

There is a high amount of particulates present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>KC97082</b>	---	---
Sample Date	Client Info	<b>25 Aug 2022</b>	---	---
Machine Age	hrs Client Info	<b>3501</b>	---	---
Oil Age	hrs Client Info	<b>3501</b>	---	---
Oil Changed	Client Info	<b>Changed</b>	---	---
Sample Status		<b>ABNORMAL</b>	---	---

## WEAR METALS

method	limit/base	current	history1	history2
Iron ppm ASTM D5185m	>50	<b>&lt;1</b>	---	---
Chromium ppm ASTM D5185m	>10	<b>0</b>	---	---
Nickel ppm ASTM D5185m	>3	<b>0</b>	---	---
Titanium ppm ASTM D5185m	>3	<b>0</b>	---	---
Silver ppm ASTM D5185m	>2	<b>0</b>	---	---
Aluminum ppm ASTM D5185m	>10	<b>&lt;1</b>	---	---
Lead ppm ASTM D5185m	>10	<b>0</b>	---	---
Copper ppm ASTM D5185m	>50	<b>12</b>	---	---
Tin ppm ASTM D5185m	>10	<b>0</b>	---	---
Vanadium ppm ASTM D5185m		<b>0</b>	---	---
Cadmium ppm ASTM D5185m		<b>0</b>	---	---

## ADDITIVES

method	limit/base	current	history1	history2
Boron ppm ASTM D5185m	0	<b>0</b>	---	---
Barium ppm ASTM D5185m	90	<b>&lt;1</b>	---	---
Molybdenum ppm ASTM D5185m	0	<b>0</b>	---	---
Manganese ppm ASTM D5185m		<b>&lt;1</b>	---	---
Magnesium ppm ASTM D5185m	100	<b>26</b>	---	---
Calcium ppm ASTM D5185m	0	<b>0</b>	---	---
Phosphorus ppm ASTM D5185m	0	<b>2</b>	---	---
Zinc ppm ASTM D5185m	0	<b>30</b>	---	---

## CONTAMINANTS

method	limit/base	current	history1	history2
Silicon ppm ASTM D5185m	>25	<b>&lt;1</b>	---	---
Sodium ppm ASTM D5185m		<b>11</b>	---	---
Potassium ppm ASTM D5185m	>20	<b>8</b>	---	---
Water % ASTM D6304	>0.05	<b>0.020</b>	---	---
ppm Water ppm ASTM D6304	>500	<b>207.1</b>	---	---






## FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm ASTM D7647		<b>12140</b>	---	---
Particles >6µm ASTM D7647	>1300	<b>▲ 6358</b>	---	---
Particles >14µm ASTM D7647	>80	<b>▲ 1455</b>	---	---
Particles >21µm ASTM D7647	>20	<b>▲ 447</b>	---	---
Particles >38µm ASTM D7647	>4	<b>▲ 45</b>	---	---
Particles >71µm ASTM D7647	>3	<b>2</b>	---	---
Oil Cleanliness ISO 4406 (c)	>--/17/13	<b>▲ 21/20/18</b>	---	---

## FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g ASTM D8045	1.0	<b>0.36</b>	---	---

# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	LIGHT	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.05	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	44.3	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color		no image	no image
Bottom		no image	no image

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KC97082  
**Lab Number** : 05629629  
**Unique Number** : 10114150  
**Test Package** : IND 2  
**Received** : 29 Aug 2022  
**Tested** : 31 Aug 2022  
**Diagnosed** : 31 Aug 2022 - Don Baldrige

**PROGRESSIVE FOAM**  
 1 SOUTHERN GATEWAY DR  
 GNADENHUTTEN, OH  
 US 44629  
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)