




# OIL ANALYSIS REPORT

Sample Rating Trend



**INSOLUBLES**



Machine Id  
**Press #3 6561231**

Component  
**Hydraulic System**

Fluid  
**KLUBER KLUBEROIL 4 UH1-46 N (251 GAL)**

## DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

MPC (Membrane Patch Colorimetry) test indicates a moderate concentration of varnish present. The amount and size of particulates present in the system are acceptable.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>PTK0003165</b>	PTK0003182	PTK0003172
Sample Date	Client Info		<b>07 Sep 2022</b>	08 Jul 2022	08 Jun 2022
Machine Age	hrs	Client Info	<b>52173</b>	50758	50172
Oil Age	hrs	Client Info	<b>6901</b>	5486	4900
Oil Changed	Client Info		<b>Not Changed</b>	Not Changed	Not Changed
Sample Status			<b>ABNORMAL</b>	MARGINAL	MARGINAL

## CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.1	<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >20	<b>7</b>	2	2
Chromium	ppm	ASTM D5185m >10	<b>&lt;1</b>	0	0
Nickel	ppm	ASTM D5185m	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >10	<b>&lt;1</b>	0	<1
Lead	ppm	ASTM D5185m >10	<b>&lt;1</b>	<1	0
Copper	ppm	ASTM D5185m >75	<b>&lt;1</b>	<1	0
Tin	ppm	ASTM D5185m >10	<b>&lt;1</b>	0	<1
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0	<1
Barium	ppm	ASTM D5185m	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	0	<1
Magnesium	ppm	ASTM D5185m	<b>&lt;1</b>	2	0
Calcium	ppm	ASTM D5185m	<b>1</b>	3	0
Phosphorus	ppm	ASTM D5185m	<b>48</b>	139	130
Zinc	ppm	ASTM D5185m	<b>12</b>	23	23
Sulfur	ppm	ASTM D5185m	<b>40</b>	56	27

## CONTAMINANTS


	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >20	<b>&lt;1</b>	3	2
Sodium	ppm	ASTM D5185m	<b>0</b>	0	0
Potassium	ppm	ASTM D5185m >20	<b>1</b>	<1	0

## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		<b>217</b>	582	307
Particles >6µm	ASTM D7647	>2500	<b>44</b>	171	137
Particles >14µm	ASTM D7647	>320	<b>5</b>	28	34
Particles >21µm	ASTM D7647	>80	<b>1</b>	10	13
Particles >38µm	ASTM D7647	>20	<b>0</b>	0	1
Particles >71µm	ASTM D7647	>4	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>18/15	<b>13/10</b>	16/15/12	14/12

# OIL ANALYSIS REPORT

### ▲ Varnish Potential



FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>0.47</b>	0.44	0.359
MPC Varnish Potential	Scale	ASTM D7843	>15	▲ <b>36</b>	▲ 17	▲ 21

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	<b>NEG</b>	NEG	NEG
Free Water	scalar	*Visual		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	<b>45.3</b>	44.9	44.9

### SAMPLE IMAGES


Color




Bottom




MPC




### Particle Count




### Acid Number



### Viscosity @ 40°C



### Particle Trend



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : PTK0003165 **Received** : 12 Sep 2022  
**Lab Number** : 05638507 **Diagnosed** : 16 Sep 2022  
**Unique Number** : 10128037 **Diagnostician** : Doug Bogart  
**Test Package** : MOB 2 ( Additional Tests: MPC )

**NIAGARA BOTTLING**  
 11031 88TH AVE  
 PLEASANT PRAIRIE, WI  
 US 53158  
 Contact: AJ

To discuss this sample report, contact Customer Service at 1-800-237-1369.


\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (909)239-7599

F:

MPC (Varnish Test)



Sample Color & Clarity



*This page left intentionally blank*