OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL

Machine Id
KAESER 10 (S/N 1059)
Component
Compressor
Fluid
HPL PREMIUM FOODE GRADE 46 (--- GAL)

DIAGNOSIS

Recommendation
Resample at the next service interval to monitor.

Wear
All component wear rates are normal.

Contamination
There is no indication of any contamination in the oil.

Fluid Condition
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**HPL0001418**	HPL0001416	RP187616
Sample Date		Client Info		**14 Sep 2022**	06 Jul 2022	08 Aug 2016
Machine Age	hrs	Client Info		**0**	72672	0
Oil Age	hrs	Client Info		**2253**	3299	0
Oil Changed		Client Info		**Not Changd**	Changed	N/A
Sample Status				**NORMAL**	NORMAL	NORMAL

CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>0.05	**NEG**	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	**2**	<1	6
Chromium	ppm	ASTM D5185m	>10	**0**	0	0
Nickel	ppm	ASTM D5185m	>3	**0**	0	<1
Titanium	ppm	ASTM D5185m	>3	**0**	0	0
Silver	ppm	ASTM D5185m	>2	**0**	0	0
Aluminum	ppm	ASTM D5185m	>10	**12**	2	18
Lead	ppm	ASTM D5185m	>10	**0**	0	<1
Copper	ppm	ASTM D5185m	>50	**2**	<1	19
Tin	ppm	ASTM D5185m	>10	**0**	<1	<1
Antimony	ppm	ASTM D5185m		**---**	---	0
Vanadium	ppm	ASTM D5185m		**0**	0	0
Cadmium	ppm	ASTM D5185m		**0**	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		**0**	<1	3
Barium	ppm	ASTM D5185m		**0**	0	<1
Molybdenum	ppm	ASTM D5185m		**0**	0	0
Manganese	ppm	ASTM D5185m		**<1**	0	<1
Magnesium	ppm	ASTM D5185m		**1**	0	<1
Calcium	ppm	ASTM D5185m		**13**	0	0
Phosphorus	ppm	ASTM D5185m		**519**	21	68
Zinc	ppm	ASTM D5185m		**31**	<1	261
Sulfur	ppm	ASTM D5185m		**2596**	1198	469

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	**0**	0	<1
Sodium	ppm	ASTM D5185m		**3**	0	2
Potassium	ppm	ASTM D5185m	>20	**1**	0	2

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		**0.30**	0.34	1.43

OIL ANALYSIS REPORT





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Precipitate	scalar	*Visual	NONE	**NONE**	NONE	NONE
Silt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Debris	scalar	*Visual	NONE	**NONE**	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Appearance	scalar	*Visual	NORML	**NORML**	NORML	NORML
Odor	scalar	*Visual	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	**NEG**	NEG	NEG
Free Water	scalar	*Visual		**NEG**	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445		**48.5**	48.8	33.8

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color			*no image*	*no image*	
Bottom			*no image*	*no image*	

GRAPHS

















Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : HPL0001418 **Recieved** : 27 Sep 2022
Lab Number : 05651632 **Diagnosed** : 29 Sep 2022
Unique Number : 10151184 **Diagnostician** : Don Baldridge
Test Package : MOB 2

DART CONTAINER
4610 AIRPORT RD
PLANT CITY, FL
US 33563
Contact: TRAY MATHESON

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: